

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Freedom Constructors Inc

Address: 298 Williams Rd
Coats, NC 27521

Date: 4-18-18

Building Official: _____

Permit Numbers
Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 17-50041787
MFG Home: _____

D. E. Tye

ADDRESS : 298 WILLIAMS RD SUBDIV: HUNTERS RUN II
CONTRACTOR : FREEDOM CONSTRUCTORS OF DUNN PHONE : (910) 892-1231
OWNER : FREEDOM CONSTRUCTORS INC PHONE : (910) 892-1231
PARCEL : 07-1600-01- -0019- - -
APPL NUMBER: 17-50041787 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/10/2017 01:37 PM JBROCK ----
27 TO COATS R ON DELMA GRIMES RD L ONTO
WILLIAMS RD LOT IS 1/2 MILE ON R
PREMISE# 66875102
CALLED IN PREMISE 9/21/17...LL 12*

STRUCTURE: 000 000 53X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : SEWER WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/17	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 003003654
	7/27/17	AP	T/S: 07/27/2017 03:29 PM DETAYLOR -----
A814 01	7/27/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003003647
	7/27/17	AP	298 WILLIAMS RD COATS 27521 T/S: 07/27/2017 10:28 AM SBENNETT -----
B103 01	9/13/17	JLP	R*BLDG FOUND & TEMP SVC POLE VRU #: 003023710
	9/13/17	AP	T/S: 09/13/2017 03:47 PM JPERRY -----
B105 01	9/27/17	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 003027992
	9/27/17	AP	T/S: 09/22/2017 08:30 AM BPETRICH ----- T/S: 09/25/2017 11:09 AM LLUCAS ----- T/S: 09/26/2017 08:23 AM BPETRICH ----- T/S: 09/27/2017 12:26 PM DETAYLOR -----
R425 01	11/08/17	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003050267
	11/08/17	DA	T/S: 11/06/2017 02:49 PM JBROCK ----- T/S: 11/08/2017 03:00 PM DETAYLOR ----- Strap garage door lvls Strap stud columns of more than three studs Okay to side and insulate
I129 01	11/14/17	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003052073
	11/14/17	AP	T/S: 11/13/2017 08:01 AM LLUCAS ----- T/S: 11/14/2017 03:55 PM DETAYLOR -----
R425 02	11/14/17	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003052081
	11/14/17	AP	T/S: 11/13/2017 08:01 AM LLUCAS ----- T/S: 11/14/2017 03:55 PM DETAYLOR -----
E209 01	4/11/18	DT	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003113149
	4/12/18	AP	T/S: 04/10/2018 01:40 PM BPETRICH ----- T/S: 04/12/2018 01:03 PM DETAYLOR -----
R429 01	4/18/18	TI	FOUR TRADE FINAL VRU #: 003115375
	4/18/18	TI	Lock Box code is 543

COMMENTS AND NOTES