

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**   X  

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Comfort Homes Inc

Address: 515 Cross Link Dr  
Angier, NC 27501

Date: 12-15-17

Building Official: D. Edge

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: 17-50041794

MFG Home: \_\_\_\_\_

Harnett County

INSPECTOR: IVR

DATE 12/15/17

-----

ADDRESS . . : 515 CROSS LINK DR SUBDIV:  
 CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242  
 OWNER . . . : TURLINGTON EDWARD #45 41436440 PHONE : (919) 553-3242  
 PARCEL . . . : 04-0664- - -0092- -17-  
 APPL NUMBER: 17-50041794 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 07/07/2017 12:54 PM DJOHNSON -- 61711868  
 CROSS LINK PLACE LOT 45  
 T/S: 07/07/2017 02:09 PM DJOHNSON -- 17242

-----

STRUCTURE: 000 000 72X36 3 BR 2 BATH ATT GRG, DECK CRAWLBONS

FLOOD ZONE . . . . : FLOOD ZONE X

# BEDROOMS . . . . . : 3.00

PROPOSED USE . . . . . : SFD

SEPTIC - EXISTING? . . . . : NEW

WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	8/15/17 8/15/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003012275 515 CROSS LINK DR ANGIER 27501 T/S: 08/15/2017 09:51 AM SBENNETT -----
B101 01	8/15/17 8/15/17	BS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003012283 T/S: 08/14/2017 12:59 PM LLUCAS ----- T/S: August 15, 2017 11:10 AM BSUTTON -----
B103 01	9/13/17 9/13/17	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003024197 T/S: 09/12/2017 02:02 PM BPETRICH ----- T/S: September 13, 2017 02:46 PM BSUTTON -----
B105 01	9/26/17 9/26/17	DT AP	R*OPEN FLOOR TIME: 17:00 VRU #: 003029931 T/S: 09/25/2017 11:57 AM BPETRICH ----- T/S: 09/26/2017 11:58 AM DETAYLOR -----
R425 01	10/16/17 10/16/17	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003039054 T/S: 10/13/2017 09:11 AM LLUCAS ----- T/S: October 16, 2017 11:51 AM BSUTTON ----- Brace trusses as shown on truss docs. 2.Girder d04 no uplift. 3. Truss to girder at D04 Missing hanger over front bedroom closet. 4. Finish roofing. Ok to side
R425 02	10/19/17 10/19/17	KS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003040755 T/S: 10/17/2017 02:54 PM BPETRICH ----- T/S: 10/19/2017 12:50 PM KSLATTUM -----
I129 01	10/23/17 10/23/17	BS DP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003042652 T/S: 10/20/2017 02:14 PM JBROCK ----- T/S: October 23, 2017 10:41 AM BSUTTON ----- Insulation is incomplete. No insulators ar jobsite. Not cancelled. \$50.re fee
I129 02	10/24/17 10/24/17	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003043007 T/S: 10/23/2017 11:07 AM LLUCAS -----
H824 01	10/25/17 10/25/17	AC AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003045184 T/S: 10/26/2017 10:37 AM KHINSON ----- T/S: 10/26/2017 10:37 AM KHINSON -----
R429 01	12/14/17 12/14/17	MC DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 003066636 T/S: 12/13/2017 12:54 PM DJOHNSON ----- T/S: 12/14/2017 11:00 AM LLUCAS ----- T/S: 12/14/2017 11:01 AM LLUCAS ----- T/S: 12/14/2017 11:17 AM MCOOK ----- 1. install cap on gas line fireplace 2. under cabinet light not installed

PREPARED 12/14/17, 14:11:24  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 29  
DATE 12/15/17

-----  
ADDRESS . . : 515 CROSS LINK DR SUBDIV:  
CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242  
OWNER . . . : TURLINGTON EDWARD #45 PHONE : (919) 553-3242  
PARCEL . . . : 04-0664- - -0092- -17-  
APPL NUMBER: 17-50041794 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	12/15/17 <u>12/15/17</u>	TI <u>AP DT</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003067162 T/S: 12/14/2017 11:01 AM LLUCAS -----

-----  
COMMENTS AND NOTES  
-----