

August 21, 2017

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Wynn Construction, Inc.  
2550 Capitol Drive, Suite 105  
Creedmoor, NC 27522

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Improvement Permit Application #17-5-41903**

Dear Mr. Averett,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other – There is available space and suitable soils for a three bedroom home. There is not enough available space and suitable soils for a four bedroom home. Based on your proposal I will need a private consultant's report for four bedrooms. Submit this as a revision to Central Permitting.

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health OSWW Specialist  
Harnett County Department of Public Health

AC/sgs  
Copy: Central Permitting