

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: RESIDENTIAL

Name: WYNN CONSTRUCTION INC.

Address: 378 AVERY POND DR.

Date: 2/1/18

Building Official: _____

M. H. H. H.

Permit Numbers

Building: 17-50041905

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

ADDRESS : 378 AVERY POND DR SUBDIV: AVERY POND PH2 30LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : WYNN CONSTRUCTION INC PHONE :
 PARCEL : 08-0653- - -0029- -62-
 APPL NUMBER: 17-50041905 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/24/2017 11:41 AM JBROCK ----
 AVERY POND #58
 401 FOR 15 MILES LEFT ON CHALYBEATA RD
 1/8 MMILE AVERY POND IS ON THE L
 T/S: 10/25/2017 09:16 AM JBROCK ----
 premise # 73001288

STRUCTURE: 000 000 60X60 4BDR 2.5BA MONO W/ GARAGE & CBAC P
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	10/09/17 10/09/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003035508 378 AVERY POND RD FUQUAY VARINA 27526 T/S: 10/09/2017 10:46 AM SBENNETT -----
P309 01	10/09/17 10/09/17	KS AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003035516 T/S: 10/06/2017 11:23 AM LLUCAS ----- T/S: 10/09/2017 12:34 PM KSLATTUM -----
B114 01	10/13/17 10/13/17	BS DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003038510 T/S: 10/12/2017 01:36 PM BPETRICH ----- T/S: October 13, 2017 09:40 AM BSUTTON ----- Piers at garage wing wall in wrong location. Pier at left rear corner at nook missing. garage center beam lugs wrong
B114 02	10/16/17 10/16/17	BS DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003039492 T/S: 10/13/2017 01:22 PM JBROCK ----- T/S: October 16, 2017 11:25 AM BSUTTON ----- not ready
B114 03	10/17/17 10/17/17	KS AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003039864 T/S: 10/16/2017 12:34 PM LLUCAS ----- T/S: 10/17/2017 10:04 AM KSLATTUM -----
B104 01	11/16/17 11/16/17	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003055035 T/S: 11/16/2017 02:54 PM JBROCK -----
R425 01	11/20/17 11/20/17	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003054962 T/S: 11/16/2017 01:50 PM JBROCK ----- T/S: November 20, 2017 10:23 AM BSUTTON ----- Nuts and washers missing at garage and dining room. 2. Repair cut studs at balloon framed wall. Ok to side and insulate
I129 01	11/22/17 11/22/17	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003056918 T/S: 11/21/2017 11:24 AM BPETRICH ----- T/S: November 22, 2017 02:13 PM BSUTTON -----
R425 02	11/22/17 11/22/17	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003056926 T/S: 11/21/2017 11:24 AM BPETRICH ----- T/S: November 22, 2017 02:13 PM BSUTTON -----
R125 01	12/13/17 12/13/17	MC AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003066032 T/S: 12/12/2017 12:23 PM LLUCAS ----- STONE PREP

ADDRESS : 378 AVERY POND DR
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : WYNN CONSTRUCTION INC
PARCEL : 08-0653- - -0029- -62-
APPL NUMBER: 17-50041905 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND PH2 30LTS
PHONE : (919) 528-1347
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E209 01	1/11/18 1/11/18	MC AP	T/S: 12/13/2017 02:27 PM MCOOK ----- R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003075025 T/S: 01/10/2018 01:40 PM BPETRICH ----- T/S: 01/11/2018 02:42 PM MCOOK -----
H824 01	1/16/18 1/16/18	AC AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003078185 T/S: 01/22/2018 10:18 AM KHINSON ----- T/S: 01/22/2018 10:18 AM KHINSON -----
M305 01	1/22/18 1/22/18	MC AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003077708 T/S: 01/19/2018 12:29 PM JBROCK ----- T/S: 01/22/2018 02:01 PM MCOOK -----
R429 01	2/01/18 <u>al</u>	TI <u>AP</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003083771 T/S: 01/31/2018 12:16 PM LLUCAS -----

COMMENTS AND NOTES