

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:


Use Classification: Residential

Name: Lamco Custom Builders

Address: 78 Brookview Ct
Angier, NC 27501

Date: 1-3-18

Building Official: _____



Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 17-50041926

MFG Home: _____

ADDRESS : 78 BROOKVIEW CT SUBDIV:
CONTRACTOR : LAMCO CUSTOM BUILDERS, LLC PHONE : (919) 859-4190
OWNER : LAMCO CUSTOM BUILDERS LLC PHONE :
PARCEL : 04-0672- - -0209- -20-
APPL NUMBER: 17-50041926 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 07/26/2017 09:37 AM JBROCK ----
THE CREEK #5
210 TO HWY 55 IN ANIGER R GO 2.5 MILES
R ONTO OLD BUISE RD GO 2 MILES LINTO
THE CREEK S/D

STRUCTURE: 000 000 32X48 4BDR 2.5BA SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BATHS : 3 # BEDROOMS : 4000000.00
PROPOSED USE : SFD SEPTIC - EXISTING? : NEW TANK
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	9/22/17 9/22/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003028545 78 BROOKVIEW CT ANGIER 27501 T/S: 09/22/2017 09:25 AM SBENNETT -----
B101 01	9/22/17 9/22/17	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 003028875 T/S: 09/21/2017 02:09 PM JBROCK ----- T/S: 09/22/2017 10:10 AM DETAYLOR ----- T/S: 09/22/2017 03:46 PM DETAYLOR
B103 01	10/04/17 10/04/17	DT AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 003033578 T/S: 10/03/2017 12:58 PM JBROCK ----- T/S: 10/04/2017 02:24 PM DETAYLOR -----
B105 01	10/10/17 10/10/17	DT AP	R*OPEN FLOOR TIME: 17:00 VRU #: 003035169 T/S: 10/06/2017 01:39 PM JBROCK ----- T/S: 10/10/2017 10:10 AM DETAYLOR -----
R425 01	11/14/17 11/14/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003051604 T/S: 11/09/2017 10:11 AM BPETRICH ----- T/S: 11/13/2017 08:04 AM LLUCAS ----- T/S: 11/14/2017 03:56 PM DETAYLOR ----- Strap garage door lvls Trusses missing bracing and strapping Trusses not completely seated in hangers Insulate and install air barriers behind fireplace Replace over bored studs at fireplace Okay to side and insulate
I129 01	11/17/17 11/17/17	DT DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003054384 T/S: 11/16/2017 08:47 AM BPETRICH ----- T/S: 11/17/2017 02:31 PM DETAYLOR ----- Trusses still not fastened to hangers Install complete air barriers at fireplace
R425 02	11/17/17 11/17/17	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003054392 T/S: 11/17/2017 02:31 PM DETAYLOR ----- Trusses still not fastened to hangers Install complete air barriers at fireplace
I129 02	12/21/17 12/21/17	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003069929

ADDRESS . : 78 BROOKVIEW CT SUBDIV:
CONTRACTOR : LAMCO CUSTOM BUILDERS, LLC PHONE : (919) 859-4190
OWNER . . : LAMCO CUSTOM BUILDERS LLC PHONE :
PARCEL . . : 04-0672- - -0209- -20-
APPL NUMBER: 17-50041926 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 03	12/21/17 12/21/17	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003069945
E209 01	12/22/17 12/22/17	DT AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003069960 T/S: 12/21/2017 09:30 AM JBROCK ----- T/S: 12/22/2017 11:58 AM DETAYLOR -----
M305 01	12/22/17 12/22/17	DT AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003069978 T/S: 12/21/2017 09:30 AM JBROCK ----- T/S: 12/22/2017 11:58 AM DETAYLOR -----
P307 01	12/22/17 12/22/17	DT AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003069986 T/S: 12/21/2017 09:30 AM JBROCK ----- T/S: 12/22/2017 11:58 AM DETAYLOR -----
H824 01	12/29/17 12/29/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003071982 T/S: 12/29/2017 09:59 AM SSTEWARD ----- T/S: 12/29/2017 09:59 AM SSTEWARD -----
R429 01	1/03/18 <u>1/3/18</u>	TI <u>AP DT</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003072121 T/S: 12/29/2017 01:15 PM BPETRICH ----- T/S: 01/02/2018 08:04 AM DJOHNSON -----

----- COMMENTS AND NOTES -----