



Permit Inspections Harnett County

	10/31/2017	10/31/2017	FOUR TRADE ROUGH IN	Unassigned	DISAPPROVED	
Notes: T/S: 10/30/2017 03:19 PM LLUCAS ----- T/S: October 31, 2017 03:01 PM BSUTTON -----						
	10/31/2017	10/31/2017	R INSULATION INSPECTION	Unassigned	DISAPPROVED WITH PEN	
Notes: T/S: October 31, 2017 09:47 AM BSUTTON ----- Previous write ups (except bath vent) Not corrected.						
	11/2/2017	11/2/2017	FOUR TRADE ROUGH IN	Unassigned	APPROVED	
Notes: T/S: 11/01/2017 03:29 PM LLUCAS ----- T/S: 11/02/2017 11:27 AM KSLATTUM -----						
	11/2/2017	11/2/2017	R INSULATION INSPECTION	Unassigned	APPROVED	
Notes: T/S: 11/02/2017 11:26 AM KSLATTUM -----						
	12/1/2017	12/1/2017	ENVIR. OPERATIONS PERMIT	Unassigned	APPROVED	
Notes: T/S: 12/04/2017 09:46 AM KHINSON ----- T/S: 12/04/2017 09:46 AM KHINSON -----						
	12/6/2017	12/6/2017	R PLUMB WATER CONNECTION	Unassigned	APPROVED	
Notes: T/S: 12/04/2017 02:50 PM LLUCAS ----- T/S: December 06, 2017 12:15 PM BSUTTON -----						
	12/6/2017	12/6/2017	R PLUMB SEWER CONNECTION	Unassigned	APPROVED	
Notes: T/S: 12/04/2017 02:50 PM LLUCAS ----- T/S: December 06, 2017 12:15 PM BSUTTON -----						
	12/8/2017	12/8/2017	R ELEC TEMP POWER CERT	Unassigned	DISAPPROVED	
Notes: T/S: 12/07/2017 09:28 AM LLUCAS ----- T/S: 12/08/2017 04:07 PM MCOOK ----- 1. CAN NOT HAVE MORE THAN 2 GROUNDS UNDER ONE LUG 2. WIRE FOR STOVE NOT PROPERLY TERMINATED 3. INSTALL LOCK OUT FOR HOOD VENT OR INSTALL DISCONNECT 4. LABEL DISWASJER DISCONNECT 5. INSTALL LOCK OUT FOR WATER HEATER						
	12/14/2017	12/14/2017	FOUR TRADE FINAL	Unassigned	DISAPPROVED	
Notes: T/S: 12/14/2017 03:38 PM MCOOK ----- 1. INSTALL LOCK OUT ON HOODVENT 2. INSTALL LOCK OUT ON WATER HEATER 3. SEAL AROUND ATTIC ACCESS DOOR JAMB						





Permit Inspections Harnett County

	12/18/2017	12/18/2017	FOUR TRADE FINAL	Unassigned	APPROVED	
--	------------	------------	---------------------	------------	----------	--

Notes:
T/S: 12/15/2017 10:12 AM BPETRICH -----
T/S: 12/18/2017 02:35 PM MCOOK ----- 1. corr. made

