

August 16, 2023

To Whom it May Concern:

Dear Sir or Madam:

I have inspected and evaluated the rough-in electrical wiring for the new single family dwelling being constructed by Mr. George Jacobs located at 37 Bernard Street in Spring Lake.

In my professional opinion, the work done meets or exceeds the 2020 NEC with the NC Amendments for 1 & 2 family dwellings as adopted.

Sincerely,

Douglas K. Stewart

Owner/Operator, Pinebluff Electric

Douglas K. Stewart

Gateway Plumbing-Licensed and Insured (James Cockerham- License # 30962)

750 Womack Road Broadway, NC 27505 919-499-7919



George Jacobs 25 Bernard Street Spring Lake, NC 28390

Upon Inspection of plumbing system:

- Removed all building drain piping and redone according to NC building code.
- Installed building sewer.
- Inserted a water test on building drain with a 3 ft head pressure above highest fixture
- Inserted 100 PSI air test on all water distribution lines for the house.

All passed test.

Property is in compliance with 2018 plumbing code.

Thank you,

James Cockerham #30962



Total Systems Heating & Cooling, Inc. 13341 Hwy 210 South (Physical) PO Box 737 (Mailing) PO Box 737 (Mailing)

13341 Hwy 210 South (Physical)
PO Box 737 (Mailing)
Spring Lake, NC 28390
Phone 910-436-3450 Fax 910-436-9103
Mech Lic #28846

<u>service@totalsystemsnc.com</u>
<u>www.totalsystemshvac.com</u>

September 13, 2023

RE: George Jacobs 25 Bernard St Spring Lake, NC 28390

To Whom it Concerns:

A Site Visit was performed at 25 Bernard St on Monday, September 11, 2023, to inspect Mechanical Systems. The Range Hood was installed as per manufacturers installation recommendations. The ductless system was installed per manufacturers recommendations.

Both Linesets must be insulated at the flare connection on each indoor unit.

The gas piping system was installed to code and pressurized.

mffall

Regards,

Jerry Hall