

HTE# 17-542031

Harnett County Department of Public Health

29550

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: GEORGE JOHN JACOBS PROPERTY LOCATION: BERNARD ST
 NEW REPAIR EXPANSION SUBDIVISION: ANDERSON CREEK LOT # 54
 Type of Structure: SFD (54x41) Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: CONVENTIONAL
 Projected Daily Flow: 240 GPD
 Number of bedrooms: 2 Number of Occupants: 4 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet
 Permit conditions: _____ Permit valid for: Five years
 No expiration

Authorized State Agent: ~~_____~~ RGMS Date: 8/22/17 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: GEORGE JOHN JACOBS PROPERTY LOCATION: BERNARD ST.
 FACILITY TYPE: SFD (54x41) New Expansion Repair
 SUBDIVISION: ANDERSON CREEK LOT # 54
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** CONVENTIONAL (Initial) Wastewater Flow: 240 GPD
 (See note below, if applicable CONVENTIONAL (Repair)
Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 3
 Pump Tank Size _____ gallons Exact length of each trench 50 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6-18 inches
 Maximum Trench Depth of: 18-30 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____
 This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: ~~_____~~ RGMS Date: 8/22/17 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 8/22/22


HTE# 17-5-42031

Permit # 29550

Harnett County Department of Public Health Site Sketch

ISSUED TO: GEORGE JOHN JACOBS PROPERTY LOCATOR: BERNARD ST.
SUBDIVISION: ANDERSON CREEK LOT # 54

Authorized State Agent: ~~XXXXXXXXXXXXXXXXXXXX~~ RENS (OLIVEL TOLKSCOTT) Date: 8/22/17



**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 8/21/17
 Proposed Facility: 20020 Design Flow (.1949): 240 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-48	G SL	VPRL NS/NP					S.6
2		0-58	G SL						
		58-28	SSK SCL						PS.5
3		0-48	G SL	VPRL NS/NP					S.1

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OK Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.5	.5	

3-50 R 28-30