

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Wyan Construction Inc.

Address: 441 Falls Creek Dr

Date: 5-29-18

Building Official: James T. Hall

Permit Numbers

Building: _____

Electrical: 17

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

50042165

ADDRESS . . : 441 FALLS CREEK DR SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . . : ANDERSON CREEK PARTNERS LP PHONE :
 PARCEL . . . : 01-0535-26- -0100- -02-
 APPL NUMBER: 17-50042165 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/29/2017 03:44 PM JBROCK ----
 ANDERSON CREEK CROSSING #91

STRUCTURE: 000 000 46.1X45.9 4BDR MONO W/ GARAGE & COV PORC

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? . . . : SEWER WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	10/06/17 10/05/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003034576 441 FALLS CREEK DR SPRING LAKE 28390 T/S: 10/05/2017 08:29 AM SBENNETT -----
E207 01	10/06/17 10/06/17	JH DA	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003034592 T/S: 10/04/2017 02:33 PM LLUCAS ----- Panel loose on pole -----
P309 01	10/06/17 10/06/17	JH AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003034584 T/S: 10/04/2017 02:16 PM JBROCK -----
B114 01	10/19/17 10/19/17	JH DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003040771 T/S: 10/17/2017 03:20 PM BPETRICH ----- Missing 30"x30" footings on corner of garage per plans & clean out loose dirt from footings.
E207 02	10/19/17 10/19/17	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003040789 T/S: 10/17/2017 03:21 PM BPETRICH -----
B114 02	10/20/17 10/20/17	JH AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003042082 T/S: 10/19/2017 01:45 PM BPETRICH -----
B104 01	11/09/17 11/09/17	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003051588 T/S: 11/09/2017 08:40 AM JBROCK ----- T/S: 11/09/2017 08:40 AM JBROCK -----
R425 01	11/29/17 11/29/17	KS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003058005 T/S: 11/27/2017 11:28 AM JBROCK ----- T/S: 11/29/2017 04:17 PM KSLATTUM ----- ANCHOR BOLTS MISSING LEFT SIDE OF GARAGE INTERIOR WALL - OK TO INSULATE & SIDE
I129 01	12/04/17 12/04/17	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003060316 T/S: 11/30/2017 01:59 PM JBROCK -----
R425 02	12/04/17 12/04/17	JH AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003060324 T/S: 11/30/2017 01:59 PM JBROCK -----
R125 01	12/22/17 12/22/17	MC AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003070125 T/S: 12/21/2017 11:42 AM DJOHNSON ----- STONE PREP T/S: 12/22/2017 03:48 PM MCOOK -----
M305 01	1/03/18 1/03/18	JH AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003072592 T/S: 01/02/2018 12:24 PM BPETRICH -----

Harnett County

INSPECTOR: IVR

DATE 5/29/18

ADDRESS . : 441 FALLS CREEK DR SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : ANDERSON CREEK PARTNERS LP PHONE :
 PARCEL . . : 01-0535-26- -0100- -02-
 APPL NUMBER: 17-50042165 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P307 01	1/03/18 1/03/18	JH AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003072600 T/S: 01/02/2018 12:25 PM BPETRICH -----
E209 01	1/12/18 1/12/18	JH AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003075090 T/S: 01/10/2018 01:52 PM LLUCAS -----
R429 01	5/04/18 5/04/18	JH DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 003123007 T/S: 05/03/2018 10:09 AM LLUCAS ----- AC oads to sit on grade. 2/6" to untreated wood from grade. Remove materials from garage for inal inspection.
R429 02	5/29/18 <i>5-29-18 AP JH</i>	TI <i>AP JH</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003132586 T/S: 05/25/2018 10:49 AM DJOHNSON -----

----- COMMENTS AND NOTES -----