

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: WYNN Construction INC.

Address: 72 Wildlife Bridge Ct

Springlake NC 28390

Date: 5-25-18

Building Official: [Signature]

Permit Numbers

Building: 17-500421166

Electrical: " "

Insulation: " "

Plumbing: " "

Mechanical: " "

MEG Home: _____

ADDRESS . : 72 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER . . : ANDERSON CREEK PARTNERS LP PHONE :
PARCEL . . : 01-0535-26- -0100- -16-
APPL NUMBER: 17-50042166 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/29/2017 03:44 PM JBROCK ----
ANDERSON CREEK CROSSING #124

STRUCTURE: 000 000 36X51.16 4BDR MONO W/ GARAGE & COV B POR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : SEWER WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	11/03/17 11/03/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003048790 72 WILDLIFE BRIDGE CT SPRING LAKE T/S: 11/03/2017 10:54 AM SBENNETT -----
M305 01	11/03/17 11/03/17	TSG AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003048907 T/S: 11/02/2017 01:09 PM BPETRICH ----- T/S: 11/03/2017 03:06 PM LLUCAS -----
P307 01	11/03/17 11/03/17	TSG AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003048915 T/S: 11/02/2017 01:09 PM BPETRICH ----- T/S: 11/03/2017 03:06 PM LLUCAS -----
P309 01	11/03/17 11/03/17	TSG AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003048782 T/S: 11/02/2017 01:05 PM BPETRICH ----- T/S: 11/03/2017 03:06 PM LLUCAS -----
B114 01	11/17/17 11/17/17	JH AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003054004 T/S: 11/15/2017 01:34 PM JBROCK ----- CHECK T-POLE TOO T-POLE PASSED -----
B104 01	12/21/17 12/21/17	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003070232
R425 01	1/11/18 1/11/18	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003073640 T/S: 01/08/2018 03:35 PM JBROCK ----- T/S: 01/09/2018 02:06 PM BPETRICH ----- 1)Move water line thats under kitchen light brackets @ kitchen door.2)Missing nail guard at top plate on gas line over fire box.3)Missing 3 studs under porch beam in garage.4)Need repair letter for damaged truss over master tub.5)10 psi on gas line test.
I129 01	1/17/18 1/19/18	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003075850 T/S: 01/12/2018 09:30 AM LLUCAS ----- T/S: 01/16/2018 08:22 AM LLUCAS -----
R425 02	1/17/18 1/19/18	JH AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003075868 T/S: 01/12/2018 09:30 AM LLUCAS ----- T/S: 01/16/2018 08:22 AM LLUCAS -----
R125 01	2/05/18 2/05/18	JH AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003084720 T/S: 02/01/2018 04:13 PM LLUCAS ----- STONE PREP
E209 01	2/26/18	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003094059

ADDRESS : 72 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER : ANDERSON CREEK PARTNERS LP PHONE :
PARCEL : 01-0535-26- -0100- -16-
APPL NUMBER: 17-50042166 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	2/26/18	DA	T/S: 02/23/2018 11:07 AM BPETRICH ----- 1)Missing receptacle over stove.2)Missing breaker @ AHU in attic for AHU.
E209 02	2/27/18	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003094794
	2/27/18	AP	T/S: 02/26/2018 01:49 PM BPETRICH -----
R429 01	5/04/18	JH	FOUR TRADE FINAL TIME: 17:00 VRU #: 003123031
	5/04/18	DA	T/S: 05/03/2018 10:10 AM LLUCAS ----- 1)Ground rods to grade.2)AC pad needs to sit on grade.3)6" from untreated wood to grade.4)24" unobstructed pathway to AHU in attic.
R429 02	5/25/18	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003131620
	<u>5/25/18</u>	<u>ABS</u>	T/S: 05/23/2018 01:39 PM JBROCK -----

----- COMMENTS AND NOTES -----