

HTE# 17-5-42291

Harnett County Department of Public Health

29226

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Richard & Rebecca Lamy

PROPERTY LOCATION: 229 Ablitzd Ln. (Young rd. sr 1546)

NEW REPAIR EXPANSION

SUBDIVISION _____ LOT # 1

Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: 3BR 46'x62' SFD

Proposed Wastewater System Type: 25% Reduction Sys

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 100 feet min

Permit valid for: Five years No expiration

Permit conditions: _____

Authorized State Agent: [Signature] Date: 09/27/2017

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Richard & Rebecca Lamy

PROPERTY LOCATION: 229 Ablitzd Ln. (Young rd. sr 1546)

Facility Type: 3BR 46'x62' SFD New Expansion Repair

SUBDIVISION _____ LOT # 1

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable)

25% Reduction System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Number of trenches 3

Pump Tank Size _____ gallons

Exact length of each trench 80 feet

Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a

Soil Cover: 6 inches

Maximum Trench Depth of: 18 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4"

in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe

_____ inches above pipe

_____ inches total

Conditions: _____

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 09/27/2017

Construction Authorization Expiration Date: 09/27/2022

HTE# 17-5-42291

Permit # 29226

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: 229 Abith Ln. (Young Rd SR 1546)

ISSUED TO: Richard & Rebecca Lenny SUBDIVISION _____ LOT # _____

Authorized State Agent: [Signature] Date: 09/27/2017



