



ADDRESS : 45 COTTLE LAKE DR SUBDIV: J L STONE  
 CONTRACTOR : WJH LLC PHONE : (336) 282-3606  
 OWNER : MASTIN BAKER INVESTMENTS LLC PHONE :  
 PARCEL : 07-0589- - -0102- -06-  
 APPL NUMBER: 17-50042294 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 09/19/2017 09:02 AM JBROCK ----  
 COTTLESTONE #2  
 210 S TAKE L ONTO S MAIN ST THEN R ONTO  
 E FRONT ST

APPL NOTES : BPMN 12/06/17 T/S: 12/06/2017 03:46 PM BPETRICH --  
 PREMISE 94017670  
 T/S: 12/07/2017 01:37 PM BPETRICH --  
 CALLED IN TEMP SVC 1:38P 12/7

**STRUCTURE: 000 000 40X50 3BDR 2.5BA MONO W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	11/21/17 11/20/17	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003055530 45 COTTLE LAKE DR COATS 27521 T/S: 11/20/2017 08:47 AM SBENNETT -----
E207 01	11/21/17 11/21/17	DT AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003055555 T/S: 11/17/2017 12:38 PM LLUCAS ----- T/S: 11/21/2017 02:41 PM DETAYLOR -----
P309 01	11/21/17 11/21/17	DT AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003055548 T/S: 11/17/2017 12:38 PM LLUCAS ----- T/S: 11/21/2017 02:41 PM DETAYLOR -----
B114 01	11/28/17 11/28/17	DT AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003081239
B104 01	1/22/18 1/22/18	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003077989 T/S: 01/22/2018 08:32 AM JBROCK -----
R425 01	1/30/18 1/30/18	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003081247 T/S: 01/25/2018 02:04 PM JBROCK ----- T/S: 01/29/2018 08:26 AM BPETRICH ----- T/S: 01/30/2018 03:31 PM DETAYLOR ----- 1. Need letter for anchor bolts 2, Air barrier missing under steps at garage 3. Fire caulk hole in top plate of front bedroom and master bath next to vent 4. Need repair for cut stud in master bath 5. Replace short nails in truss hangers in garage 6. Need bottom plate for air barrier in upstairs closet 7. Hurrican straps must be nailed to actual truss 8. AO1C trussmissing second hurricane strap at front door wall 9. B02L girder truss not strapped for uplift 10. A3CS trusses not strapped at front wall Okay to side
R425 02	2/08/18 2/08/18	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003086444 T/S: 02/07/2018 08:20 AM BPETRICH ----- T/S: 02/08/2018 01:42 PM DETAYLOR -----
I129 01	2/12/18 2/12/18	KS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003087806 T/S: 02/09/2018 10:07 AM LLUCAS -----

-----  
ADDRESS : 45 COTTLE LAKE DR SUBDIV: J L STONE  
CONTRACTOR : WJH LLC PHONE : (336) 282-3606  
OWNER : MASTIN BAKER INVESTMENTS LLC PHONE :  
PARCEL : 07-0589- - -0102- -06-  
APPL NUMBER: 17-50042294 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E209 01	3/06/18 3/06/18	DT AP	T/S: 02/12/2018 12:30 PM KSLATTUM ----- R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003097177 T/S: 03/02/2018 02:04 PM LLUCAS ----- T/S: 03/06/2018 01:32 PM DETAYLOR -----
H824 01	3/07/18 3/07/18	AC AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003099504 T/S: 03/08/2018 09:46 AM KHINSON ----- T/S: 03/08/2018 09:46 AM KHINSON -----
R429 01	3/16/18 <u>3-16-18</u>	TI <u>APBS</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003102381 T/S: 03/15/2018 01:17 PM BPETRICH -----

----- COMMENTS AND NOTES -----