

HTE# 17-S-42320

Harnett County Department of Public Health

29228

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Lanco Custom Bldg, LLC

PROPERTY LOCATION: 14 Brookview Ct. (Old Buies Creek Rd.)
SUBDIVISION: The Creek LOT # 9

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 3BR 48'x42' SFD

Proposed Wastewater System Type: 25% Reduction Sys

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well _____ feet

Permit valid for: Five years
 No expiration

Permit conditions: _____

Authorized State Agent: [Signature]

Date: 09/28/2017

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Lanco Custom Bldg, LLC

PROPERTY LOCATION: 14 Brookview Ct. (Old Buies Creek Rd.)
SUBDIVISION: The Creek LOT # 9

Facility Type: 3BR 48'x42' SFD New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% reduction system (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable)

25% Reduction System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 3

Exact length of each trench 80 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 34 inches

(Trench bottoms shall be level to +/-1/4"

in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 12 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe

_____ inches above pipe

_____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature]

Date: 09/28/2017

ANDREW CURRIN

Construction Authorization Expiration Date: 09/28/2022


HTE# 17-5-42320

Permit # 29228

Harnett County Department of Public Health Site Sketch

ISSUED TO: Lumco Custom Bids, LLC PROPERTY LOCATOR: 14 Brookview Ct. (Old Boies Creek Rd.) ^{SR 1542}
SUBDIVISION: The Creek LOT # 9

Authorized State Agent: *Andrew Corrin* Date: 09/28/2017
ANDREW CORRIN



**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: Lanico Custom Bldg LLC
 Address: The Creek Lot 9 Date Evaluated: 09/27/17
 Proposed Facility: 362 SFS Design Flow (.1949): 300 GPD Property Size: 0.77 AC
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 3%	0-24	CL LS	Very Silty Clay					
		24-40	BK SLL	FI Silty Sp					PS
		40+	Parent mat.	-		40			0.4
3	L 3%	0-30	CL LS	Very Silty Clay					
		30-48	BK SLL	FI Silty Sp					PS
		40+	Parent mat.	-		48			0.4
4	L 3%	0-24	CL LS	Very Silty Clay					
		24-36	BK SLL	FI Silty Sp					PS
		36+	Parent mat.	-		36			0.4
5	L 3%	0-12	CL LS	Very Silty Clay					PS
		12-18	BK SLL	FI Silty Sp	7.5 YR 7.1 @ 16"	18+			0.4

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <u>Provisionally Suitable</u>
System Type(s)	<u>25% MS</u>	<u>25% MS</u>	Evaluated By: <u>Andrew Curran, AETS</u>
Site LTAR	<u>0.4</u>	<u>0.4</u>	Others Present: