

HTE# 17-5-40434

Harnett County Department of Public Health

29766

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 5098 NC 27 East

ISSUED TO: William + Ranee Puckett

SUBDIVISION

LOT #

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 50' x 138' x 119' SFD

Proposed Wastewater System Type: 25% reduction sys.

Projected Daily Flow: 600 GPD

Number of bedrooms: 6 Number of Occupants: 12 max

Basement Yes NoPump Required: Yes No May be required based on final location and elevations of facilitiesType of Water Supply: Community Public Well Distance from well 100+ feetPermit conditions: Permit valid for: Five years No expirationAuthorized State Agent: *John Puckett* Date: 12/01/2017

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: William + Ranee Puckett

PROPERTY LOCATION: 5098 NC 27 East

LOT #

Facility Type: 50' x 138' x 119' SFD New Expansion RepairBasement? Yes No Basement Fixtures? Yes NoType of Wastewater System** 25% reduction sys. *III* (Initial) Wastewater Flow: 600 GPD(See note below, if applicable)

25% reduction sys. (Repair)

Installation Requirements/Conditions

Septic Tank Size 1250 gallons

Number of trenches 4

Pump Tank Size _____ gallons

Exact length of each trench 100 feet

Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a

Soil Cover: 12 inches

Maximum Trench Depth of: 24 inches

(Maximum soil cover shall not exceed

(Trench bottoms shall be level to +/- 1/4"

36" above the trench bottom)

in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe

Conditions: _____ inches above pipe _____ inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: *John Puckett* Date: 12/01/2017
Andrew Curran Construction Authorization Expiration Date: 12/01/2023

HTE# 17-S-42434

Permit # 29766

Harnett County Department of Public Health Site Sketch

ISSUED TO: William + Range Puckett

PROPERTY LOCATON: 5098 NC 27 East.

SUBDIVISION _____

LOT # _____

Authorized State Agent: Andrew Warren

ANDREW WARREN

Date: 12/01/2017

