

ADDRESS : 82 ALEAH CT  
 CONTRACTOR : WJH LLC  
 OWNER : WJH LLC  
 PARCEL : 11-0680-01- -0090- -78-  
 APPL NUMBER: 17-50042468 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 10/05/2017 10:05 AM JBROCK ----  
 E ON FRONT TOWARD 1ST ST TAKE 421 S TO  
 LESLIE CAMPBELL AVE IN NEILLS CREEK  
 CONT ON LESLIE CAMPBELL TO ANNA ST  
 LOT 193

SUBDIV: MEADOWS@BUIES CREEK  
 PHONE : (336) 282-3606  
 PHONE :

**STRUCTURE: 000 000 24X24 3BSR 2.5BA MONO**

FLOOD ZONE : FLOOD ZONE X  
 # BATHS : 2.5 # BEDROOMS : 3000000.00  
 PROPOSED USE : SFD SEPTIC - EXISTING? : SEWER  
 WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	12/29/17 1/02/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003071784 82 ALEAH CT LILLINGTON 27546 T/S: 01/02/2018 12:22 PM SBENNETT -----
P309 01	1/02/18 1/02/18	DT CA	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003071792 T/S: 12/28/2017 01:57 PM LLUCAS ----- T/S: 12/28/2017 01:58 PM LLUCAS ----- T/S: 12/29/2017 08:25 AM BPETRICH ----- T/S: 01/02/2018 01:57 PM DETAYLOR -----
P309 02	1/10/18 1/10/18	DT AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003074101 T/S: 01/09/2018 11:44 AM LLUCAS ----- T/S: 01/10/2018 03:20 PM DETAYLOR -----
B114 01	1/22/18 1/22/18	DT DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003076239 T/S: 01/12/2018 01:46 PM BPETRICH ----- T/S: 01/19/2018 01:52 PM BPETRICH ----- T/S: 01/22/2018 09:30 AM DETAYLOR ----- Per plans lug must be 18 inches wide
B114 02	1/23/18 1/23/18	DT AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003078326 T/S: 01/22/2018 10:56 AM DJOHNSON ----- T/S: 01/23/2018 03:38 PM DETAYLOR -----
B104 01	2/01/18 2/01/18	BP AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003084589 T/S: 02/01/2018 01:31 PM BPETRICH ----- T/S: 02/01/2018 01:31 PM BPETRICH -----
R425 01	2/16/18 2/16/18	DT DA	FOUR TRADE ROUGH IN VRU #: 003090158 T/S: 02/16/2018 11:09 AM DETAYLOR ----- Install necessary anchor bolts per code Replace cap on plumbing dead end in pantry with cleanout Install structural nail guards for breaks in bottom plate Okay to side
R425 02	3/01/18 3/01/18	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003095122 T/S: 02/27/2018 12:57 PM DJOHNSON ----- T/S: 02/28/2018 09:24 AM LLUCAS ----- T/S: 03/01/2018 03:43 PM LLUCAS -----
I129 01	3/05/18 3/05/18	DT DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003096849 T/S: 03/02/2018 11:17 AM JBROCK ----- T/S: 03/05/2018 02:43 PM BPETRICH -----

ADDRESS . . : 82 ALEAH CT  
CONTRACTOR : WJH LLC  
OWNER . . . : WJH LLC  
PARCEL . . . : 11-0680-01- -0090- -78-  
APPL NUMBER: 17-50042468 CP NEW RESIDENTIAL (SFD)

SUBDIV: MEADOWS@BUIES CREEK  
PHONE : (336) 282-3606  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 02	3/07/18 3/07/18	DT AP	MISSING INSULATION AROUND WINDOWS R*INSULATION INSPECTION TIME: 17:00 VRU #: 003098332 T/S: 03/06/2018 01:04 PM BPETRICH ----- T/S: 03/07/2018 04:05 PM BPETRICH -----
M305 01	3/07/18 3/07/18	DT AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003098357 T/S: 03/06/2018 01:04 PM BPETRICH ----- T/S: 03/07/2018 04:05 PM BPETRICH -----
P307 01	3/07/18 3/07/18	DT AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003098340 T/S: 03/06/2018 01:04 PM BPETRICH ----- T/S: 03/07/2018 04:05 PM BPETRICH -----
E209 01	4/04/18 4/04/18	DT AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003110210 T/S: 04/03/2018 01:46 PM BPETRICH ----- T/S: 04/04/2018 03:35 PM DETAYLOR -----
R429 01	5/29/18 5/29/18	DT DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 003132180 T/S: 05/24/2018 01:37 PM BPETRICH ----- T/S: 05/29/2018 01:02 PM DETAYLOR ----- Incorrect address EEC incomplete
R429 02	5/31/18 <u>5/31/18</u>	TI <u>AP DJ</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003133543 T/S: 05/30/2018 10:29 AM BPETRICH ----- ENERGY CERTIFICATE WILL BE UNDER THE KITCHEN SINK

----- COMMENTS AND NOTES -----