

ADDRESS . . : 94793 \*UNASSIGNED SUBDIV:  
CONTRACTOR : WJH LLC PHONE : (336) 282-3606  
OWNER . . : OLDE FARM VILLAGE LLC PHONE :  
PARCEL . . : 01-0504- - -0125- -35-  
APPL NUMBER: 17-50042504 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 10/09/2017 10:36 AM JBROCK ----  
OLDE FARM #19 - HALLOW OAK ST

STRUCTURE: 000 000 38X34 4BDR 2.5BA MONO W/ GARAGE

FLOOD ZONE . . . . : FLOOD ZONE X  
# BATHS . . . . . : 2.5 # BEDROOMS . . . . . : 4000000.00  
PROPOSED USE . . . . . : SFD SEPTIC - EXISTING? . . . . : SEWER  
WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

| TYP/SQ  | REQUESTED COMPLETED  | INSP RESULT | DESCRIPTION RESULTS/COMMENTS  |
|---------|----------------------|-------------|---|
| A814 01 | 12/07/17<br>12/07/17 | TW<br>AP    | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003064094<br>118 Hallow Oak St Lot 19 Spring Lake 28390<br>***home faces Hallow Oak St<br>T/S: 12/07/2017 04:09 PM TWARD -----  |
| P309 01 | 1/24/18<br>1/24/18   | JH<br>DA    | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003078789<br>T/S: 01/22/2018 02:09 PM JBROCK -----<br>10' head test on plumbing -----   |
| E207 01 | 1/26/18<br>1/26/18   | JH<br>AP    | R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003080843<br>T/S: 01/25/2018 10:34 AM JBROCK -----  |
| P309 02 | 1/26/18<br>1/26/18   | JH<br>AP    | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003080835<br>T/S: 01/25/2018 10:33 AM JBROCK -----  |
| B114 01 | 2/20/18<br>2/20/18   | JH<br>CA    | R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003091196<br>T/S: 02/19/2018 10:31 AM LLUCAS -----<br>PER BRIAN -----   |
| B114 02 | 2/21/18<br>2/21/18   | JH<br>DA    | R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003091923<br>T/S: 02/20/2018 11:16 AM BPETRICH -----<br>Lug footing at garage/porch wal doesn't match plans   |
| B114 03 | 2/22/18<br>2/22/18   | JH<br>AP    | R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003092533<br>T/S: 02/21/2018 10:20 AM JBROCK -----  |
| B104 01 | 3/20/18<br>3/20/18   | BP<br>AP    | R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003104346<br>T/S: 03/20/2018 04:52 PM BPETRICH -----<br>T/S: 03/20/2018 04:53 PM BPETRICH -----   |
| R425 01 | 3/22/18<br>3/22/18   | JH<br>CA    | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003104353<br>T/S: 03/20/2018 04:53 PM BPETRICH -----<br>PER BRIAN NO PLANS   |
| R425 02 | 4/03/18<br>4/03/18   | JH<br>DA    | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003108859<br>T/S: 03/29/2018 03:36 PM BPETRICH -----<br>1)Missing 2-2x4 in back right corner of garage per plans.2)Replace short nails in floor truss hangers in living room & roof truss hangers in front left bed with correct size nails.3)Fire caulk pipes @ top plate in spare bath & master bath sink.4)3' head of water on drain line test. |
| R425 03 | 4/09/18<br>4/09/18   | JH<br>AP    | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003111945<br>T/S: 04/06/2018 01:20 PM JBROCK -----   |
| I129 01 | 4/12/18              | JH          | R*INSULATION INSPECTION TIME: 17:00 VRU #: 003113552  |

-----  
 ADDRESS . : 94793 \*UNASSIGNED SUBDIV:  
 CONTRACTOR : WJH LLC PHONE : (336) 282-3606  
 OWNER . . : OLDE FARM VILLAGE LLC PHONE :  
 PARCEL . . : 01-0504- - -0125- -35-  
 APPL NUMBER: 17-50042504 CP NEW RESIDENTIAL (SFD)  
 -----

| TYP/SQ  | REQUESTED COMPLETED | INSP RESULT  | DESCRIPTION RESULTS/COMMENTS  |
|---------|---------------------|--------------|---|
| M305 01 | 4/12/18             | AP           | T/S: 04/11/2018 01:01 PM BPETRICH -----   |
|         | 4/24/18             | JH           | R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003117900   |
|         | 4/24/18             | CA           | T/S: 04/23/2018 01:35 PM JBROCK -----   |
|         |                     |              | T/S: 04/24/2018 04:00 PM jhall -----  |
| P307 01 | 4/24/18             | JH           | R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003117918   |
|         | 4/24/18             | CA           | T/S: 04/23/2018 01:35 PM JBROCK -----   |
|         |                     |              | T/S: 04/24/2018 04:00 PM jhall -----  |
| M305 02 | 5/01/18             | JH           | R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003120490   |
|         | 5/01/18             | AP           | T/S: 04/30/2018 08:31 AM JBROCK -----   |
| P307 02 | 5/01/18             | JH           | R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003120508   |
|         | 5/01/18             | AP           | T/S: 04/30/2018 08:32 AM JBROCK -----   |
| E209 01 | 6/04/18             | BS           | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003134590   |
|         | 6/04/18             | DA           | T/S: 06/01/2018 09:44 AM JBROCK -----   |
|         |                     |              | T/S: June 04, 2018 02:01 PM BSUTTON -----   |
|         |                     |              | BONDING SCREW IN NEUTRAL LUG WILL NOT TIGHTEN. CONTRACTOR TO INSTALL A LUG AND #4 COPPER BONDING JUMPER FROM NEUTRAL TO BOX. EVERYTHING ELSE IS OK. |
| E209 02 | 6/07/18             | JH           | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003136892   |
|         | 6/07/18             | AP           | T/S: 06/06/2018 01:52 PM JBROCK -----   |
| R429 01 | 7/03/18             | TI           | FOUR TRADE FINAL TIME: 17:00 VRU #: 003147170   |
|         | <u>7-3-18</u>       | <u>AP TH</u> | T/S: 07/02/2018 12:41 PM JBROCK -----   |

----- COMMENTS AND NOTES -----