

HTE# 17-5-42844

Harnett County Department of Public Health

29821

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ATLANTIC CONST. INC PROPERTY LOCATION: WILL LUCAS RD
 NEW REPAIR EXPANSION SUBDIVISION: SNEGWATER LOT # 25
 Type of Structure: SFO (50'x50') Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCTION SYSTEM
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: ~~REMS~~ Date: 12/21/17 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: ATLANTIC CONST. INC PROPERTY LOCATION: WILL LUCAS RD
 Facility Type: SFO (50'x50') New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable 25% RGD. Sys. (Repair)

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>1</u>	
Pump Tank Size _____ gallons	Exact length of each trench <u>230</u> feet	Trench Spacing: <u>9</u> Feet on Center
	Trenches shall be installed on contour at a	Soil Cover: <u>24-36</u> inches
	Maximum Trench Depth of: <u>36-48</u> inches	(Maximum soil cover shall not exceed
	(Trench bottoms shall be level to +/-1/4"	36" above the trench bottom)
	in all directions)	
Pump Requirements: _____ ft. TDH vs. _____ GPM		_____ inches below pipe
		Aggregate Depth: _____ inches above pipe
Conditions: _____		_____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: ~~REMS~~ Date: 12/21/17
 Construction Authorization Expiration Date: 12/21/22

HTE# 17-5-48844

Permit # 29821

Harnett County Department of Public Health Site Sketch

ISSUED TO: ATLANTIC CONST., INC PROPERTY LOCATOR: WILL LUCAS R
SUBDIVISION SWEET-WATER LOT # 25

Authorized State Agent: ~~REDA~~ (OLIVER TOLSON) Date: 12/21/17

* CALL WITH ANY QUESTIONS
PRIOR TO INSTALLATION

* KEEP SYSTEM 10' FROM
SIDE PROPERTY LINE
TO ALLOW FOR
ENOUGH REPAIR
AREA.



