

ADDRESS . . : 245 REMINGTON HILL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . . : ALBATROSS INVESTMENTS LLC
 PARCEL . . . : 01-0525-01- -0095- -36-
 APPL NUMBER: 17-50042959 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/19/2017 10:17 AM JBROCK ----
 GATEWEST #36

SUBDIV: GATEWEST 53 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 47.11X44 4BDR 3BA MONO W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BATHS : 3
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW TANK

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/06/18 2/06/18	JH AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003085560 T/S: 02/05/2018 12:01 PM BPETRICH ----- T-POLE ALSO :) T_POLE PASSED
A814 01	2/16/18 2/16/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003089968 245 REMINGTON HILL DR BUNNLEVEL 28323 T/S: 02/16/2018 12:03 PM SBENNETT -----
B114 01	2/16/18 2/16/18	JH DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003089976 T/S: 02/15/2018 10:51 AM BPETRICH ----- T/S: 02/16/2018 03:22 PM JHALL -----
B114 02	3/15/18 3/15/18	JH AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003101797 T/S: 03/14/2018 11:35 AM DJOHNSON ----- ENGINEER LETTER IN BOX
B104 01	5/04/18 5/04/18	BP AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003123924 T/S: 05/04/2018 11:40 AM BPETRICH ----- T/S: 05/04/2018 11:40 AM BPETRICH -----
R425 01	5/07/18 5/07/18	JH DP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003123932 T/S: 05/04/2018 11:48 AM BPETRICH ----- 1)Nail all lvls every 12" per documents.2)Missing nails in hurricane straps throughout house.3)Nail & hurricane strap all 2 & 3 ply trusses per truss documents.4)100 psi on water line test.5)fire caulk hole over light switch in living room.6)Gap to big on side porch between rafter & ridge beam.7)Nail osb to left of kitchen window.8)Missing anchor bolts to left of kitchen window & on interior load bearing walls.9)Fire caulk hole in top plate at half bath sink.10)Header plans for first floor show 2x12 headers on plans.11)Missing receptacle in backleft bedroom 6' from door & right bed 6' each side from case opening.12)3' head of water on drain line test.13)Missing hurricane straps on back wall in garage.14)Make up wires in outside boxes.15)Nai nail house wrap per installation instructions. DO NOT SIDE OR INSULATE
R425 02	5/10/18 5/10/18	JH DP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003125713 T/S: 05/09/2018 12:08 PM BPETRICH ----- ITEMS3 11,12 & 14 NOT CORRECTED
I129 01	5/14/18 5/14/18	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003127040 T/S: 05/11/2018 02:48 PM DJOHNSON -----

ADDRESS : 245 REMINGTON HILL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : ALBATROSS INVESTMENTS LLC
PARCEL : 01-0525-01- -0095- -36-
APPL NUMBER: 17-50042959 CP NEW RESIDENTIAL (SFD)

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 977-2562
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 03	5/14/18	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003126752
	5/14/18	AP	T/S: 05/11/2018 11:40 AM DJOHNSON
M305 01	5/30/18	TSG	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003133139
	5/30/18	AP	T/S: 05/29/2018 11:10 AM LLUCAS
P307 01	5/30/18	TSG	T/S: 05/30/2018 04:05 PM DJOHNSON
	5/30/18	AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003133147
			T/S: 05/29/2018 11:10 AM LLUCAS
R125 01	6/18/18	JH	T/S: 05/30/2018 04:05 PM DJOHNSON
	6/18/18	AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003140928
			T/S: 06/15/2018 10:08 AM BPETRICH
H824 01	7/02/18	OT	STONE PREP
	7/02/18	DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003147097
			PER OLIVER PUMP TO BE CHECKED FOR FINAL. CALL WHEN READY 910-893-7547
			PER OLIVER PUMP TO BE CHECKED FOR FINAL. CALL WHEN READY 910-893-7547
E209 01	7/03/18	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003147261
	7/03/18	AP	T/S: 07/02/2018 01:36 PM BPETRICH
H824 02	7/03/18	OT	LOCK BOX CODE IS 5383
	7/03/18	AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 003148202
			T/S: 07/05/2018 10:05 AM KHINSON
R429 01	7/10/18	TI	T/S: 07/05/2018 10:05 AM KHINSON
	<i>7-10-18</i>	<i>AP TH</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003149564
			T/S: 07/09/2018 11:47 AM DJOHNSON
			DOOR LOCK BOX NUMBER IS 5383.

COMMENTS AND NOTES