

# RJB, P.E., P.A.

C-0269

ROBERT J. BRACKEN  
ENGINEER + SURVEYOR

3768 Carbonton Road • Sanford, North Carolina 27330  
(919) 774-6074 • bjbracken@windstream.net

October 30, 2018

Harnett County Building Inspections  
P.O. Box 65  
Lillington, NC 27546



REF: Residence @  
265 Woodrun  
Carolina Lakes S/D  
Harnett Co.  
Michael Ryan Homes, Cont.

Dear Sir/Madam:

I made an onsite visit to the above referenced residential building site on October 30, 2018. The purpose of the visit was to examine the material and compaction that was used at the site for a proposed residence.

The building footings were in the fill area. The material, was processed fill and the compaction procedure used in the fill areas was adequate . I also used a hand held penetrometer and got consistant readings of 2000 lbs or better throughout the footing trenches. The proposed footings will meet or exceed the requirements set forth in the N.C. Residential Building Code, 2012 ed.

If you have any questions please feel free to call me at 919-774-6074.

Sincerely,

A handwritten signature in cursive script that reads "Robert J. Bracken".

Robert J. Bracken, PE

RJB:jeb

