
ADDRESS : 34 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER : WYNN CONSTRUCTION INC PHONE :
PARCEL : 01-0535-26- -0100- -19-
APPL NUMBER: 17-50042974 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/21/2017 08:47 AM JBROCK -----
ANDERSON CREEK CROSSING #127 - 34
WILDLIFE RIDGE CT

STRUCTURE: 000 000 45.7X48 4BDR 2.5BA W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BATHS : 2.5 # BEDROOMS : 4000000.00
PROPOSED USE : SFD SEPTIC - EXISTING? : SEWER
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| A814 01 | 2/05/18 2/02/18 | SB AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003084670 34 WILDLIFE BRIDGE CT SPRING LAKE 28390 T/S: 02/02/2018 12:21 PM SBENNETT ----- |
| E207 01 | 2/05/18 2/05/18 | JH AP | R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003085016 T/S: 02/02/2018 01:15 PM LLUCAS ----- |
| P309 01 | 2/05/18 2/05/18 | JH AP | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003084688 T/S: 02/01/2018 04:12 PM LLUCAS ----- |
| B114 01 | 2/12/18 2/12/18 | JH AP | R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003087814 T/S: 02/09/2018 10:53 AM JBROCK ----- |
| B104 01 | 3/19/18 3/19/18 | LL AP | R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003103231 T/S: 03/19/2018 11:36 AM LLUCAS ----- T/S: 03/19/2018 11:37 AM LLUCAS ----- |
| R425 01 | 3/20/18 3/20/18 | JH DA | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003103249 T/S: 03/19/2018 11:37 AM LLUCAS ----- 1)Need structural nail guard over electrical panel in garage.2)Nail all holes in floor truss hangers in living room.3)5 studs under 2 ply lvls @ stairs per plans.4)Fire caulk hole in top plate to left of fire box.5)Need 4 studs under 2ply lvls in dining room per plans.6)Missing stud under window in front right bedroom closet on joint. |
| I129 01 | 3/23/18 3/23/18 | JH AP | R*INSULATION INSPECTION TIME: 17:00 VRU #: 003105061 T/S: 03/22/2018 11:13 AM BPETRICH ----- |
| R425 02 | 3/23/18 3/23/18 | JH AP | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003105053 T/S: 03/22/2018 11:13 AM BPETRICH ----- |
| R125 01 | 4/11/18 4/11/18 | JH DA | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003113131 T/S: 04/10/2018 01:39 PM BPETRICH ----- STONE PREP Lath laps backwards |
| R125 02 | 4/12/18 4/12/18 | JH AP | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003113487 T/S: 04/11/2018 12:18 PM LLUCAS ----- STONE PREP |
| M305 01 | 4/27/18 4/27/18 | JH AP | R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003119468 T/S: 04/26/2018 11:31 AM JBROCK ----- |
| P307 01 | 4/27/18 | JH | R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003119476 |

ADDRESS . . : 34 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER . . : WYNN CONSTRUCTION INC PHONE :
PARCEL . . : 01-0535-26- -0100- -19-
APPL NUMBER: 17-50042974 CP NEW RESIDENTIAL (SFD)

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| E209 01 | 4/27/18 | AP | T/S: 04/26/2018 11:31 AM JBROCK ----- |
| | 5/01/18 | JH | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003120466 |
| | 5/01/18 | AP | T/S: 04/27/2018 04:17 PM LLUCAS ----- |
| R429 01 | 5/18/18 | JH | FOUR TRADE FINAL TIME: 17:00 VRU #: 003129087 |
| | 5/18/18 | DA | T/S: 05/16/2018 03:56 PM LLUCAS ----- 1)Energy certificate not filled out.2)Caulk toilets.3)Need cleanout cover in laundry room.4)Missing cleanout on right side of house.5)Grade away from house 6" in 10' in back right corner.6)Cleanouts to grade. |
| R429 02 | 5/25/18 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 003131604 |
| | <u>5-25-18</u> | <u>APBS</u> | T/S: 05/23/2018 01:39 PM JBROCK ----- |

----- COMMENTS AND NOTES -----