

Harnett County

INSPECTOR: IVR

DATE 6/07/18

ADDRESS . . : 24 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : WYNN CONSTRUCTION INC PHONE :
 PARCEL . . : 01-0535-26- -0100- -20-
 APPL NUMBER: 17-50042975 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/21/2017 08:56 AM JBROCK ----
 ANDERSON CREEK CROSSING #128 - 24
 WILDLIFE BRIDGE CT

STRUCTURE: 000 000 37X53.5 4BDR 2.5BA MONO W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BATHS : 2.5 # BEDROOMS : 4000000.00
 PROPOSED USE : SFD SEPTIC - EXISTING? : SEWER
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	2/05/18 2/02/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003084696 24 WILDLIFE BRIDGE CT SPRING LAKE 28390 T/S: 02/02/2018 12:20 PM SBENNETT -----
E207 01	2/05/18 2/05/18	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003085032 T/S: 02/02/2018 01:16 PM LLUCAS -----
P309 01	2/05/18 2/05/18	JH AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003084704 T/S: 02/01/2018 04:13 PM LLUCAS -----
B114 01	2/14/18 2/14/18	JH DA	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003089018 T/S: 02/13/2018 01:32 PM BPETRICH ----- Missing lug footings on garage wing walls per plans-----
B114 02	2/15/18 2/15/18	JH AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003089422 T/S: 02/14/2018 11:24 AM LLUCAS -----
B104 01	3/27/18 3/27/18	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003107570 T/S: 03/27/2018 03:16 PM JBROCK -----
R425 01	4/02/18 4/02/18	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003108438 T/S: 03/29/2018 09:50 AM LLUCAS ----- 1)Missing anchor bolt to right of kitchen sink.2)Anchor all interior load bearing walls per code.3)Missing nail guards at top plate in front right bed closet.4)Fire block hole under spare bath tub.5)Make up wires on outside receptacles.6)Holes in house wrap.
I129 01	4/06/18 4/06/18	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003110327 T/S: 04/03/2018 02:18 PM JBROCK ----- T/S: 04/04/2018 10:44 AM LLUCAS -----
R425 02	4/06/18 4/06/18	JH AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003110301 T/S: 04/03/2018 02:14 PM JBROCK ----- T/S: 04/04/2018 10:44 AM LLUCAS -----
R125 01	4/26/18 4/26/18	JH AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003118718 T/S: 04/25/2018 08:51 AM DJOHNSON ----- STONE PREP
M305 01	4/27/18 4/27/18	JH AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003119484 T/S: 04/26/2018 11:31 AM JBROCK -----
P307 01	4/27/18 4/27/18	JH AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003119492 T/S: 04/26/2018 11:31 AM JBROCK -----
E209 01	5/18/18	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003129236

ADDRESS . : 24 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER . . : WYNN CONSTRUCTION INC PHONE :
PARCEL . . : 01-0535-26- -0100- -20-
APPL NUMBER: 17-50042975 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	5/18/18	AP	T/S: 05/17/2018 10:46 AM BPETRICH -----
R429 01	<u>6-7-18</u>	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 003136462
		<i>APJ</i>	T/S: 06/06/2018 11:13 AM LLUCAS -----

----- COMMENTS AND NOTES -----