
 ADDRESS . . : 14 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : ANDERSON CREEK PARTNERS LP PHONE :
 PARCEL . . : 01-0535-26- -0100- -21-
 APPL NUMBER: 17-50042976 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/21/2017 09:04 AM JBROCK -----
 ANDERSON CREEK CROSSING #129 - 14
 WILDLIFE BRIDGE CT

STRUCTURE: 000 000 34X44 4BDR 2.5BA MONO W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BATHS : 2.5 # BEDROOMS : 4000000.00
 PROPOSED USE : SFD SEPTIC - EXISTING? : SEWER
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	2/23/18 2/26/18	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003093010 14 WILDLIFE BRIDGE CT LOT 129 SPRING LAKE 28390 T/S: 02/26/2018 11:56 AM TWARD ----- T/S: 02/26/2018 11:57 AM TWARD -----
P309 01	3/06/18 3/06/18	JH AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003097508 T/S: 03/05/2018 10:03 AM BPETRICH -----
B114 01	3/09/18 3/09/18	JH AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003099561 T/S: 03/08/2018 10:05 AM BPETRICH ----- -----
M305 01	3/09/18 3/09/18	JH AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003099579 T/S: 03/08/2018 10:05 AM BPETRICH ----- -----
P307 01	3/09/18 3/09/18	JH AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003099587 T/S: 03/08/2018 10:05 AM BPETRICH ----- -----
E207 01	3/19/18 3/19/18	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 003102803 T/S: 03/16/2018 11:31 AM LLUCAS ----- FOGOT TO SCHEDULE WITH MONO
B104 01	4/12/18 4/12/18	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003113958 T/S: 04/12/2018 10:54 AM JBROCK -----
R425 01	4/16/18 4/16/18	JH CA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003114386 T/S: 04/13/2018 09:16 AM LLUCAS ----- per craig
R425 02	4/17/18 4/17/18	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003115029 T/S: 04/16/2018 10:40 AM LLUCAS ----- 1)Hold down straps in back right corner per plans.2)100 psi on water line test.3)Nail 3ply trusses per truss documents.
I129 01	4/19/18 4/19/18	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 003116027 T/S: 04/18/2018 10:12 AM BPETRICH ----- T/S: 04/19/2018 03:23 PM DETAYLOR -----
R425 03	4/19/18 4/19/18	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003116001 T/S: 04/18/2018 10:12 AM BPETRICH ----- T/S: 04/19/2018 03:23 PM DETAYLOR -----
R125 01	5/07/18 5/07/18	JH AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003123866 T/S: 05/04/2018 11:33 AM JBROCK ----- stone inspection
E209 01	5/25/18	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003131562

ADDRESS : 14 WILDLIFE BRIDGE CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : ANDERSON CREEK PARTNERS LP
PARCEL : 01-0535-26- -0100- -21-
APPL NUMBER: 17-50042976 CP NEW RESIDENTIAL (SFD)

SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
PHONE : (919) 528-1347
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	5/25/18	AP	T/S: 05/23/2018 01:37 PM JBROCK T/S: May 25, 2018 02:25 PM BSUTTON
R429 01	6/19/18	JH	FOUR TRADE FINAL TIME: 17:00 VRU #: 003141579
	6/19/18	DA	T/S: 06/18/2018 12:26 PM BPETRICH 1)Handrails lower than 34" & less than 1 1/4" off wall per code
R429 02	<u>6/21/18</u>	TI <i>APJH</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003142866 T/S: 06/20/2018 01:17 PM BPETRICH

COMMENTS AND NOTES