

HTE #: 18-5-43063R

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Joseph Cooper

Phone #: 919.413.4033

Address: P.O. Box 13282 Durham, NC 27709

Name of Mobile Home Park or S/D: NA

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): US 401 N. - PIN - 0654-58-2919.000
PID - 080654 0096

Purpose of Inspection: Three (3) bedroom SFD (49'x50') on location of existing system with formerly permitted shared mobile homes (2). Proposed SFD not within septic field, repair area, and meets septic setbacks. Existing system verified located 5ft min. off proposed SFD location and ends 10ft min. off property line.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

02/12/2018

Date