

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: — Applicant: Triangle Home Props
 Address: Cokesbury Park C9 Date Evaluated: 01/26/2018
 Proposed Facility: 302 SFD Design Flow (.1949): 300 GPD Property Size: 0.35 AC
 Location of Site: Property Recorded: YES
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L 4-8%	0-24	GR LS	VA 4H/4g					PS
		24-44	BR SLL	FA 5SS/4g	7.5YR 7/1 @ 40"	44			0.4
3	L 4-8%	0-24	GR LS	VA 4H/4g					U/PS
		24-36	BR SLL	FA 5H/1g	7.5YR 7/1 @ 34"	36			0.4

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <u>Unsuitable/Provisionally Suitable</u>
System Type(s)	<u>25% ud</u>	<u>25% rc</u>	Evaluated By: <u>Andrew Curran REAS</u>
Site LTAR	<u>0.4</u>	<u>0.4</u>	Others Present: