

ADDRESS : 90 WILDLIFE BRIDGE CT SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : WYNN CONSTRUCTION INC PHONE :
 PARCEL : 01-0535-26- -0100- -15-
 APPL NUMBER: 18-50043169 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/26/2018 09:55 AM JBROCK ----
 ANDERSON CREEK CROSSING #123

STRUCTURE: 000 000 37X60.5 4BDR 2.5BA MONO W/ GARAGE & CBP
 FLOOD ZONE : FLOOD ZONE X
 # BATHS : 2.5 # BEDROOMS : 4000000.00
 PROPOSED USE : SFD SEPTIC - EXISTING? : SEWER
 WATER SUPPLY : COUNTY


PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| A814 01 | 4/02/18 4/02/18 | SB AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003108602 90 WILDLIFE BRIDGE CT SPRING LAKE 28390 T/S: 04/02/2018 10:56 AM SBENNETT ----- |
| P309 01 | 4/02/18 4/02/18 | JH DA | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003108594 T/S: 03/29/2018 11:07 AM BPETRICH ----- 10' head of water on drain line test |
| P309 02 | 4/03/18 4/03/18 | JH AP | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 003109576 T/S: 04/02/2018 01:32 PM BPETRICH ----- |
| B114 01 | 4/05/18 4/05/18 | JH AP | R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 003110582 T/S: 04/04/2018 10:45 AM LLUCAS ----- PLS CHECK T-POLE ALSO T-POLE PASSED |
| M305 01 | 4/27/18 4/27/18 | JH AP | R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 003119435 T/S: 04/26/2018 11:30 AM JBROCK ----- |
| P307 01 | 4/27/18 4/27/18 | JH AP | R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 003119450 T/S: 04/26/2018 11:30 AM JBROCK ----- |
| B104 01 | 5/03/18 5/03/18 | JB AP | R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 003123049 T/S: 05/03/2018 10:11 AM JBROCK ----- |
| R425 01 | 5/04/18 5/04/18 | JH DP | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003123056 T/S: 05/03/2018 10:11 AM JBROCK ----- 1)Missing anchor bolts on back wall in garage.2)Fire caulk hole in top plate to right of electrical panel in garage.3)Anchor bolt both sides of door in garage.4)Loose osb under window to left of fire box.5)Missing nail guards on water lines @ frig.6)Nail loose osb in front right bed closet.7)3' head of water on drain line test NO WATER IN TEST. |
| R425 02 | 5/08/18 5/08/18 | JH AP | OK TO SIDE DO NOT INSULATE FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 003124336 T/S: 05/07/2018 10:44 AM BPETRICH ----- |
| I129 01 | 5/11/18 5/11/18 | JH AP | R*INSULATION INSPECTION TIME: 17:00 VRU #: 003125754 T/S: 05/09/2018 12:12 PM LLUCAS ----- |
| R125 01 | 5/23/18 5/23/18 | JH AP | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 003130440 T/S: 05/21/2018 03:35 PM BPETRICH ----- STONE PREP |
| E209 01 | 6/20/18 6/20/18 | MC DA | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003141900 T/S: 06/19/2018 09:44 AM BPETRICH ----- T/S: 06/20/2018 03:14 PM MCOOK ----- |

ADDRESS : 90 WILDLIFE BRIDGE CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : WYNN CONSTRUCTION INC
PARCEL : 01-0535-26- -0100- -15-
APPL NUMBER: 18-50043169 CP NEW RESIDENTIAL (SFD)

SUBDIV: ACC CROSSING PH8 SECT2A 21LTS
PHONE : (919) 528-1347
PHONE :

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| E209 02 | 6/22/18 | JH | 1.no attic access R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003143096 |
| R429 01 | 6/22/18 | AP | T/S: 06/20/2018 04:08 PM BPETRICH |
| | 7/06/18 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 003148301 |
| | | | T/S: 07/05/2018 11:36 AM LLUCAS |



COMMENTS AND NOTES