

43331

Enoch **E**ngineers, P.A.

Consulting Engineers & Surveyors

1403 NC Highway 50 South
Benson, North Carolina 27504

Phone: (919) 894-5731

(919) 894-7765

Fax: (919) 894-8190

Email: general@enochengineers.com

Joe E. Godwin Sr., P.E., P.L.S.

Fleet Temple, P.E.

Jason E. Godwin, P.L.S.

March 26, 2018

Comfort Homes
Post Office Box 369
Clayton, North Carolina 27528

C/o Russell Phillips

RE: Lot 23 & 24 @Oxford Woods Subdivision
17 Clarendon Court
Angier, North Carolina 27501


Subject: Footing Inspection (2 lots)

To Whom It May Concern:

Enoch Engineers made an initial site visit for Lot(s) 23 and 24 March 26, 2018 where a footing inspection was performed. Footings that were excavated were probed and found to be in excess of 2000 lbs. per square foot. We recommend excavating any excess eroded soil and/or remaining root matter. We also recommend dewatering the footing before any concrete placement.

If we may be of further assistance, please feel free to call.

Respectfully,



Joe E. Godwin, Sr., P.E.
Enoch Engineers, P.A.



jeg.sr/jeg

3.26.2018