



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: ANDREW CURRIN

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BLVD
Lillington, NC 27546

Joshua & Lauren Woorley
391 Shady Brook Ln.
Fuquay Varina, NC 27526

EIN: 566000306EH

Delivery: NC Courier

Harnett County

StarLiMS ID: **ES180925-0103**

Date Collected: 09/24/2018

Time Collected: 15:30

By: Andrew Currin

Date Received: 09/25/2018

Time Received: 08:42

By: Susan Beasley

Sample Source: New Well

Sampling Point: Well head

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. 18-5-43344R

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/25/2018
E. coli	Absent			09/25/2018

Report Date: 09/27/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.

North Carolina Division of Public Health
Occupational and Environmental Epidemiology Branch, Epidemiology Section
BIOLOGICAL ANALYSIS REPORT

Private well water information and recommendations

County: Harnett Name: Joshua Lauren Wootley Sample ID Number: ES180925-0403
Location: 391 Shady Brook Ln. Fuquay-Varina, NC 27526 Reviewer Andrew Curran, NCHS
Initial Sample Confirmation Sample

BIOLOGICAL ANALYSIS RESULTS AND RECOMMENDATIONS FOR USES OF YOUR PRIVATE WELL WATER (These recommendations are based on biological analysis only.)

No coliform bacteria were found in your well water. Your water can be used for all purposes including drinking, cooking, washing dishes, bathing and showering.

Total coliform bacteria were detected in the sample which indicates that harmful bacteria from human or animal waste could enter the well. Do not use the water for drinking or cooking unless it has been boiled for 3 minutes. You may use your water for all other purposes including washing dishes, bathing or showering.

Your well water needs to be re-tested to verify that the result is accurate.

Fecal coliform bacteria were detected in the sample. Do not use the water for drinking, cooking, washing dishes, bathing or showering.

If the re-test shows contamination by bacteria contact your local health department for assistance. There may be a problem with the construction of the well, the groundwater source, or operation of the well. The well needs to be inspected by the local health department or a local well contractor to determine the problem with the well and to give guidance on how to correct the problem.

Your well water was tested for biological contaminants (total coliform and fecal coliform bacteria). The results were evaluated using the federal drinking water standards.

Drinking water may contain substances that can occur naturally in water or can be introduced into water from man-made sources. Total coliform bacteria are found in soil and fecal coliform bacteria are found in animal and human waste. Total coliform or fecal coliform bacteria in well water indicate that the well may have structural problems or that the well was not properly disinfected.

If you have been drinking the well water and are pregnant, nursing, have a child in the household under 5 years of age, or immunocompromised (such as an individual with AIDS, cancer, hepatitis, dialysis or surgical procedures) inform your physician of these results at your next visit.

If the contamination continues, you should investigate the possibility of drilling a new well or installing a point-of-entry disinfection unit which can use chlorine, ultraviolet light, or ozone.

For further information please contact your county health department or the Occupational and Environmental Epidemiology Branch at 919-707-5900.



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

Certificate of Analysis

FINAL REPORT

Report to: ANDREW CURRIN

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH
 307 CORNELIUS HARNETT BLVD
 LILLINGTON, NC 27546

Joshua & Lauren Worley
 391 Shady Brook Ln
 Fuquay Varina, NC 27526

EIN: 566000306EH

Delivery: NC Courier

StarLiMS ID: **ES180925-0013**

Date Collected: 09/24/2018

Time Collected: 15:30

By: A Currin

Date Received: 09/25/2018

Time Received: 07:41

Sample Type: Raw

Sampling Point: Well head

Well Permit No. 18-5-43344R

Sample Source: New Well

Receipt Temp.: 2.6 °C

GPS No.

Comment:

Profile: New Well I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	<0.005	0.010	mg/L	
Barium	0.27	2.0	mg/L	
Cadmium	<0.001	0.005	mg/L	
Calcium	26		mg/L	
Chloride	<5	250	mg/L	
Chromium	<0.01	0.10	mg/L	
Copper	<0.05	1.3	mg/L	
Fluoride	<0.2	4	mg/L	
Iron	<0.1	0.30	mg/L	
Lead	<0.005	0.015	mg/L	
Magnesium	2		mg/L	
Manganese	0.34	0.05	mg/L	
Mercury	<0.0005	0.002	mg/L	
Nitrate	<1	10.0	mg/L	
Nitrite	<0.1	1.00	mg/L	
pH	7.5		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.05	0.10	mg/L	
Sodium	6.9		mg/L	
Sulfate	9.02	250	mg/L	
Total Alkalinity	77		mg/L	
Total Hardness	75		mg/L	
Zinc	<0.05	5.00	mg/L	

Report Date: 10/05/2018

Reported By: **Debbie Moncol**



Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

County: Harnett

Name: Joshua & Lauren Worley

Sample ID #: ES180925-0013

Reviewer: Andrew Corrin, NCHS
391 Shady Brook Ln., Fuquay-Varina

TEST RESULTS AND USE RECOMMENDATIONS

- Your well water meets federal drinking water standards *for inorganic chemicals*. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*. You may have other water sampling results that are not taken into account in this report.
- The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking, unless you install a water treatment system to remove the circled substance(s). However, it may be used for washing, cleaning, bathing and showering based on the *inorganic chemical results only*.

Arsenic	Barium	Cadmium	Chromium	Copper	Fluoride	Lead	Iron	
Manganese	Mercury	Nitrate/Nitrite	Selenium	Silver	Magnesium	Zinc	pH	

- a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the *inorganic chemical results only*.

 b. Levels over 30 mg/l may pose aesthetic problems such as bad taste, odor, staining of porcelain, etc.
- Re-sampling is recommended in _____ months.
- Re-sample for lead and /or copper. Take a first draw, 5 minute, and 15 minute sample inside the house (preferably the kitchen) and if possible a first draw, 5 minute and a 15 minute sample at the well head to determine the source of the lead and/or copper.
- The following substance(s) exceeded federal drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the *inorganic chemical results only*, but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.

Barium	Cadmium	Chromium	Fluoride	Iron	Magnesium
Manganese	Selenium	Silver	pH	Zinc	

For more information regarding your well water results, please call the North Carolina Division of Public Health at 919-707-5900. The Environmental Protection Agency (EPA) considers Manganese as secondary contaminants which means it does NOT have a direct impact on health.