

## Harnett County

Inspections  
108 East Front Street  
Lillington , NC 27546

Phone: 910-893-7525  
Fax: 910-893-2793

### Inspection Report

**Permit:** CPSF18-50043426

**OWNER:** CEDAR CREEK BUILDING COMPANY

**Site Address:** 280 GWENDOLYN WAY FUQUAY-VARINA, NC 27526

---

Harnett County Inspections Department

Inspection Type: FOUNDATION

Inspection Date: 10/04/2018

Result: DISAPPROVED

Remarks:

Notes: 1. Foundation not damp proofed 2. foundation interior piers not inspected prior to grading interior 3. remove dirt from around interior piers call for reinspection

All violations are subject to reinspection fees at the inspectors discretion.

**Ken Slattum**

Inspector