

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: James Cregger PROPERTY LOCATION: Old Boies Creek rd. (SR 271) 1542
 NEW REPAIR EXPANSION SUBDIVISION _____ LOT # _____
 Type of Structure: 432 95'x86' SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% Reduction Sys.
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 06/18/2018 03/20/2018 (AK) SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: James Cregger PROPERTY LOCATION: Old Boies Creek rd. (SR 271) 1542
 Facility Type: 432 95'x86' SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 480 GPD 580 (AK)
 (See note below, if applicable 25% Reduction System (Repair) 480 GPD (SFD) / 100 GPD (SHED)
 Installation Requirements/Conditions
 Septic Tank Size 1250 gallons Number of trenches 4
 Pump Tank Size _____ gallons Exact length of each trench 100 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: NA inches below pipe
 Conditions: On Contour D-Box Equal Distribution NA inches above pipe
NA inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 03/20/2018 06/18/2018
ANDREW WRAIN Construction Authorization Expiration Date: 03/20/2023 06/18/2023

18-5-43490 (SHED)

HTE# 18-5-43489R (SFD)

Permit # 29921

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Old Buies Creek Rd (SR ~~2271~~ 1542)

ISSUED TO: James Cregger

SUBDIVISION

LOT #


06/18/2018

Authorized State Agent:

Andrew Curran
ANDREW CURRAN

Date:

~~03/20/2018~~



* Tank shall be located downhill from SFD in proximity to shed to allow fall from shed both

* May require to meet onsite prior to install