Department of Environment, Health and Natural Desources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #: Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Ray nor Blds Inc.		
Address: (at 5) Date Evaluated: 67 1074618		
Proposed Facility. 220 SES Design Flow (.1949). See Ses	Property Size:	0.59 AC
Location of Site: Property Recorded: 183		00110
Water Supply: Public Individual Well	☐ Spring	Other
Evaluation Method: Auger Boring Pit Cut		
Type of Wastewater: Sewage Industrial Process	☐ Mixed	

P R O F I	.1940 Landscape Position/ Slope %	Horizon Depth (ln.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
L E #			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1,2,3	L<3%	0.28	GL LS	Va 554 516					P5
		28-48	BNSL	12 559 5Ep		48			P5
							1		

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948): Provisionally Suitable
Available Space (.1945)	19		Evaluated By:
System Type(s)	25% rec	25% 4d	Others Present: Andrew Currin, NEHS
Site LTAR	34	0.4	

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

0.4 - 0.1

SC-SANDY CLAY **STRUCTURE**

IV

MINERALOGY SLIGHTLY EXPANSIVE

SIC-SILTY CLAY


EXPANSIVE

C-CLAY

SG-SINGLE GRAIN M- MASSIVE CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY PR-PRISMATIC

Show profile locations and other site features (dimensions, references or benchmark, and North) 1701





DISTRICT PA 30 USE STD

SEEDROOMS 3BD

SEEDROOMS 3BD

SEEDROOMS 3BD

SEEDROOMS 3BD

SEEDROOMS 3BD