29945

HTE# 18-5-4381

## Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit
PROPERTY LOCATION: 837 Cokesbury Park Lo. (Cokesbury Red.
ISSUED TO: Friggle Home Pros., LL SUBDIVISION Concessory Rack LOT # 68
NEW REPAIR   EXPANSION   Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: 38Q 521×55' 5FD  Proposed Wastewater System Type: 355' Colonia 5
Proposed Wastewater System Type: 25% reduction Sys- Projected Daily Flow: 366 GPD
Number of bedrooms: 3 Number of Occupants: max
Basement Ves ANO
Pump Required: Pes No May be required based on final location and elevations of facilities
Type of Water Supply:   Community Public   Well Distance from well feet Permit valid for: Five years
Permit conditions: No expiration
Authorized State Agent:
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
SR 1407
ISSUED TO: Triangle Home Pros., LLC PROPERTY LOCATION: 837 Collesburg Park Co. (Collesburg Russian) Collesburg Park Lot # 68
SUBDIVISION COKESSUCY Park LOT # 68
Facility Type: 3BR 52'XSS STO New Expansion Repair
Basement?  Yes  No Basement Fixtures?  No
Type of Wastewater System** Pump to 25% Reduction 5.5. (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable □)
Pump to 25% Red a Sys_ (Repair)
Installation Requirements/Conditions Number of trenches
Septic Tank Size 1006 gallons Exact length of each trench 225 feet Trench Spacing: 7 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: inches
Maximum Trench Depth of: 1 Co inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to $\pm 1/4$ " 36" above the trench bottom)
in all directions)
Pump Requirements:ft. TDH vs GPM inches below pipe
Aggregate Depth: inches above pipe
Conditions: IMPORTED SOIL MAY BE REQUIRED NA inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Level Browner in Control
Owner/Legal Representative Signature:
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
Alice to the state of the state
Authorized State Agent:
ADONEW CORRUCTION Authorization Expiration Date: 04/26/2023

## Harnett County Department of Public Health Site Sketch

SR 1407 PROPERTY LOCATON: 837 Coresbury Park La. (Colesbury Rd. ISSUED TO: Triangle Home Prob., LL SUBDIVISION Corresburg Park LOT # GE 1111 MHS Date: 04/26/2018 Authorized State Agent: \_\_\_ XIMPORTED SOIL MAY BE REQUIRED \* SYSTEM SHALL BE INSTALLED W/ 15 FT SIDE DRAINAGE SETBACK & 10FT POLO SETBACK \*SYSTEM SHALL BE INSTALLED TO ALLOW MAXIMUM REPAIR (HIGH IN LOT AS PUSSIBLE) \* PROPERTY TRONS & LINES SHALL BE MARKED CLEARLY 20° DRA1-3REE PT STI AT-GRADE 25% PROPOSED REDUCTION REPAIR 55' x 52' AREA 300 SAS 251 0/0 351 116.00 COKESBURY PARK