HTE# 18-5-43927

Harnett County Department of Public Health

PERMIT # 30072

Operation Permit

No. 26570

SL1403

☒ New Installation ☒ Septic Tank ☒ Nitrification Line ☐ Repair ☐ Expansion

PROPERTY LOCATION: 468 CEDAR ROCK TRL (COVESBURY D)

Name: (owner) ROBB SCHIESL   SUBDIVISION CEDAR ROCK   LOT # 7

System Installer: DENIS MEDDUN   Registration # _____

Basement with plumbing: ☐   Garage ☒ Number of Bedrooms 4

Type of Water Supply: ☐ Community   ☒ Public   ☐ Well   Distance from well NA feet

System Type: ____ 25% REDUCTION SYS. IIIB ____ Types V and VI Systems expire in 5 years.

(In accordance with Table V a)   Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

INSTALL: 09/02/2020

PUMP + ALARM: 12/17/2020

* PUMP TO D-BOX EQUAL DISTRIBUTION

* SMALL TREES [MOSTLY PINES] LEFT IN SEPTIC AREA OWNER NOTIFIED IT IS BEST TO REMOVE ALL BUT OWNER STATED HOMEOWNERS ASSOC. WOULD NOT ALLOW

SFD

120'

50% RED. HORIZONTAL PPBPS REPAIR

225'

64 CHAMBER 70(S) 1850 TRENCH

17'

10'

CEDAR ROCK TRL

PERMIT CONDITIONS:

I.   Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____

Subsurface system operator required? Yes ☐ No ☐

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

_____

V.   Other: _____

☐ _____ D-Box   ☐ _____ Pump   ☐ _____ Alarm   ☐ _____ H20Line   ☐ _____ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: ☐ Conventional   ☒ Other 64 CHAMBER IIIB   Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field   No. of ditches 5   exact length of each ditch 70 feet   width of ditches 3 feet   depth of ditches 18 inches

French Drain Required: _____   Linear feet _____

Authorized State Agent _____   Date 12/17/2020