

RE: 1587200 - H&H-Onsite/Dawson/459/Chicora

Trenco  
818 Soundside Rd  
Edenton, NC 27932

**Site Information:**

Project Customer: H and H On Site Project Name: 1587200  
Lot/Block: Subdivision: Chicora  
Model:  
Address: 459 River Bluff Dr  
City: DUNN State: NC

**General Truss Engineering Criteria & Design Loads (Individual Truss Design Drawings Show Special Loading Conditions):**

Design Code: IRC2015/TPI2014 Design Program: MiTek 20/20 8.2  
Wind Code: ASCE 7-10 Wind Speed: 130 mph Design Method: MWFRS (Envelope)/C-C hybrid Wind ASCE 7-10  
Roof Load: 40.0 psf Floor Load: N/A psf  
Mean Roof Height (feet): 25 Exposure Category: C

No.	Seal#	Truss Name	Date
1	I36623613	D02	4/4/19
2	I0	B02	4/4/19

The truss drawing(s) referenced above have been prepared by MiTek USA, Inc. under my direct supervision based on the parameters provided by Builders FirstSource-Sumter,SC.

Truss Design Engineer's Name: Sevier, Scott

My license renewal date for the state of North Carolina is December 31, 2019.

**IMPORTANT NOTE:** The seal on these truss component designs is a certification that the engineer named is licensed in the jurisdiction(s) identified and that the designs comply with ANSI/TPI 1. These designs are based upon parameters shown (e.g., loads, supports, dimensions, shapes and design codes), which were given to MiTek or TRENCO. Any project specific information included is for MiTek's or TRENCO's customers file reference purpose only, and was not taken into account in the preparation of these designs. MiTek or TRENCO has not independently verified the applicability of the design parameters or the designs for any particular building. Before use, the building designer should verify applicability of design parameters and properly incorporate these designs into the overall building design per ANSI/TPI 1, Chapter 2.




Job 1587200	Truss D02	Truss Type COMMON	Qty 1	Ply 1	H&H-Onsite/Dawson/459/Chicora	Units: 1 Eng: JK	I36623613
----------------	--------------	----------------------	----------	----------	-------------------------------	---------------------	-----------

Builders FirstSource, Sumter, SC - 29153,

8.220 s Nov 16 2018 MiTek Industries, Inc. Wed Apr 3 13:29:14 2019 Page 1


ID:N9ZpzacWqWTLjEbWrVVGbZzQOD-3Ti7hywGSqj0lSP\_BtcdKmlc9hz3ploZTYZu9kzUPq3



REPAIR: TOP CHORD BROKEN AT EDGE OF PLATE AT JOINT 7  
OVERHANG IS INTACT

5x8 ||

Scale = 1:49.3



APPLY 2 X 6 X 6' SP NO.2 SCAB TO ONE FACE OF TRUSS AS SHOWN. ATTACH WITH (0.131" X 3") NAILS PER THE FOLLOWING NAIL SCHEDULE: 3 ROWS: SPACED @ 2" O.C. USE 2" MEMBER END DISTANCE.




Plate Offsets (X,Y)-- [2:0-2-8,0-0-1], [6:0-5-2,0-0-1], [8:0-4-0,0-3-0]

LOADING (psf)	SPACING-	2-0-0	CSI.	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL	1.15	TC 0.42	Vert(LL)	-0.12	8-11	>999	MT20	244/190
TCDL 10.0	Lumber DOL	1.15	BC 0.82	Vert(CT)	-0.22	8-11	>999		
BCLL 0.0 *	Rep Stress Incr	YES	WB 0.19	Horz(CT)	-0.05	2	n/a		
BCDL 10.0	Code IRC2015/TPI2014		Matrix-AS	Wind(LL)	0.13	8-11	>999		
								Weight: 108 lb	FT = 20%

**LUMBER-**  
 TOP CHORD 2x6 SP No.2  
 BOT CHORD 2x4 SP No.2  
 WEBS 2x4 SP No.3  
 SLIDER Left 2x6 SP No.2 1-11-12, Right 2x6 SP No.2 1-11-12

**BRACING-**  
 TOP CHORD Structural wood sheathing directly applied.  
 BOT CHORD Rigid ceiling directly applied.

**REACTIONS.** (lb/size) 2=788/0-5-8, 6=788/0-5-8  
 Max Horz 2=-251(LC 10)  
 Max Uplift 2=-198(LC 12), 6=-198(LC 13)  
 Max Grav 2=875(LC 19), 6=875(LC 20)

**FORCES.** (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.  
 TOP CHORD 2-4=-931/286, 4-6=-931/286  
 BOT CHORD 2-8=-74/714, 6-8=-74/714  
 WEBS 4-8=0/496

- NOTES-**
- Unbalanced roof live loads have been considered for this design.
  - Wind: ASCE 7-10; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; Cat. II; Exp C; Enclosed; MWFRS (envelope) gable end zone and C-C Exterior(2) zone; end vertical left and right exposed; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
  - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
  - \* This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members, with BCDL = 10.0psf.
  - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 100 lb uplift at joint(s) except (jt=lb) 2=198, 6=198.
  - This truss design requires that a minimum of 7/16" structural wood sheathing be applied directly to the top chord and 1/2" gypsum sheetrock be applied directly to the bottom chord.



April 4, 2019

**WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 10/03/2015 BEFORE USE.**

Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 218 N. Lee Street, Suite 312, Alexandria, VA 22314.



818 Soundside Road  
Edenton, NC 27932


Job 1587200	Truss B02	Truss Type ATTIC	Qty 7	Ply 1	H&H-Onsite/Dawson/459/Chicora	Units: 1 Eng: JK
----------------	--------------	---------------------	----------	----------	-------------------------------	---------------------

Builders First Source, Sumter SC


ID: N9ZpacWqWTLijEbWrvVGBzZQOD-bjl6eigNpqoPxcKXKWmEiXlqw7rEoff6msE060zUOzY

8.220 s Nov 3 2018 MiTek Industries, Inc. Wed Apr 3 14:27:23 2019 Page 1

REPAIR: PLATE DAMAGED AT JOINT 6



ATTACH 1/2" PLYWOOD OR OSB GUSSET (15/32" RATED SHEATHING 32/16 EXP 1) TO EACH FACE OF TRUSS WITH (0.131" X 2.5" MIN.) NAILS PER THE FOLLOWING NAIL SCHEDULE: 2 X 3'S - 2 ROWS, 2 X 4'S - 3 ROWS, 2 X 6'S AND LARGER - 4 ROWS: SPACED @ 4" O.C. NAILS TO BE DRIVEN FROM BOTH FACES. STAGGER SPACING FROM FRONT TO BACK FACE FOR A NET 2" O.C. SPACING IN EACH COVERED TRUSS MEMBER. USE 2" MEMBER END DISTANCE.



LOADING (psf)	SPACING-	CSL	DEFL.	in (loc)	l/defl	L/d	PLATES	GRIP
TCLL 20.0	Plate Grip DOL 1.15	TC 0.46	Vert(LL) -0.15	9-10	>999	360	MT20	244/190
TCDL 10.0	Lumber DOL 1.15	BC 0.44	Vert(CT) -0.22	9-10	>897	240		
BCLL 0.0 *	Rep Stress Incr YES	WB 0.43	Horz(CT) 0.00	9	n/a	n/a		
BCDL 10.0	Code IRC2015/TPI2014	Matrix-AS	Wind(LL) 0.04	10	>999	240	Weight: 248 lb	FT = 20%

LUMBER-	BRACING-
TOP CHORD 2x6 SP No.2	TOP CHORD Sheathed, except end verticals, and 2-0-0 oc purlins (6-0-0 max.): 3-5.
BOT CHORD 2x6 SP No.2 *Except* 8-10: 2x10 SP DSS	BOT CHORD Rigid ceiling directly applied.
WEBS 2x4 SP No.3 *Except* 2-10,6-9: 2x6 SP No.2, 12-13,1-11,7-8: 2x4 SP No.2	WEBS 1 Row at midpt 10-12, 9-13, 1-11, 7-8
	JOINTS 1 Brace at Jt(s): 14

**REACTIONS.** (lb/size) 11=824/0-3-8, 9=1078/0-5-8  
Max Horz 11=91(LC 8)  
Max Grav 11=1090(LC 26), 9=1447(LC 2)

**FORCES.** (lb) - Max. Comp./Max. Ten. - All forces 250 (lb) or less except when shown.  
TOP CHORD 1-2=-370/28, 2-3=-514/254, 3-4=-871/450, 4-5=-871/450, 5-6=-416/250, 6-7=-251/6, 1-11=-1125/20, 7-8=-997/24  
BOT CHORD 9-10=-38/259  
WEBS 10-12=-496/300, 2-12=-388/313, 9-13=-794/354, 6-13=-686/369, 1-10=-107/897, 7-9=-147/965, 3-14=-396/613, 4-14=-422/283, 5-14=-372/791

- NOTES-**
- 1) Unbalanced roof live loads have been considered for this design.
  - 2) Wind: ASCE 7-10; Vult=130mph (3-second gust) Vasd=103mph; TCDL=6.0psf; BCDL=6.0psf; h=25ft; Cat. II; Exp C; Enclosed; MWFRS (envelope) gable end zone and C-C Exterior(2) zone; C-C for members and forces & MWFRS for reactions shown; Lumber DOL=1.60 plate grip DOL=1.60
  - 3) Provide adequate drainage to prevent water ponding.
  - 4) This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
  - 5) \* This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 2-0-0 wide will fit between the bottom chord and any other members.
  - 6) Ceiling dead load (5.0 psf) on member(s). 12-14, 13-14; Wall dead load (5.0psf) on member(s).10-12, 9-13
  - 7) Bottom chord live load (40.0 psf) and additional bottom chord dead load (5.0 psf) applied only to room. 9-10
  - 8) This truss design requires that a minimum of 7/16" structural wood sheathing be applied directly to the top chord and 1/2" gypsum sheetrock be applied directly to the bottom chord.
  - 9) Graphical purlin representation does not depict the size or the orientation of the purlin along the top and/or bottom chord. Graphical purlin representation does not depict the size or the orientation of the purlin along the top and/or bottom chord.
  - 10) Attic room checked for L/360 deflection.



April 4, 2019

**WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE MII-7473 rev. 10/03/2015 BEFORE USE.**


Design valid for use only with MiTek® connectors. This design is based only upon parameters shown, and is for an individual building component, not a truss system. Before use, the building designer must verify the applicability of design parameters and properly incorporate this design into the overall building design. Bracing indicated is to prevent buckling of individual truss web and/or chord members only. Additional temporary and permanent bracing is always required for stability and to prevent collapse with possible personal injury and property damage. For general guidance regarding the fabrication, storage, delivery, erection and bracing of trusses and truss systems, see **ANSI/TPI1 Quality Criteria, DSB-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 218 N. Lee Street, Suite 312, Alexandria, VA 22314.




818 Soundside Road  
Edenton, NC 27932

# Symbols

## PLATE LOCATION AND ORIENTATION



For 4 x 2 orientation, locate plates 0-  $\frac{1}{16}$ " from outside edge of truss.




\* Plate location details available in **MITrak 20/20 software or upon request.**

## PLATE SIZE

4 X 4


The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

## LATERAL BRACING LOCATION



Indicated by symbol shown and/or by text in the bracing section of the output. Use T or I bracing if indicated.

## BEARING




Indicates location where bearings (supports) occur. Icons vary but reaction section indicates joint number where bearings occur. Min size shown is for crushing only.

## Industry Standards:

ANSI/TPI 1: National Design Specification for Metal Plate Connected Wood Truss Construction.  
DSB-89: Design Standard for Bracing.  
BCSI: Building Component Safety Information, Guide to Good Practice for Handling, Installing & Bracing of Metal Plate Connected Wood Trusses.

# Numbering System



**JOINTS ARE GENERALLY NUMBERED/LETTERED CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.**

**CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.**

## PRODUCT CODE APPROVALS

ICC-ES Reports:

ESR-1311, ESR-1352, ESR1988  
ER-3907, ESR-2362, ESR-1397, ESR-3282

Trusses are designed for wind loads in the plane of the truss unless otherwise shown.

Lumber design values are in accordance with ANSI/TPI 1 section 6.3 These truss designs rely on lumber values established by others.

© 2012 MITTEK® All Rights Reserved



MITek Engineering Reference Sheet: MII-7473 rev. 10/03/2015



# General Safety Notes

**Failure to Follow Could Cause Property Damage or Personal Injury**

1. Additional stability bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative Tor I bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by ANSI/TPI 1.
7. Design assumes trusses will be suitably protected from the environment in accord with ANSI/TPI 1.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with ANSI/TPI 1 Quality Criteria.