

**Howerton Services, PLLC**  
**License # P-1716**  
2108 Karns Place  
Raleigh, NC 27614  
(919) 270-3460

January 21, 2019


Subject: Smith Residence  
Harnett County Permit #: CPSF18-50044239  
Framing Inspection

Based on a request of the Contractor, I inspected 2 modified framing items for code compliance:

Item 1: In lieu of Let In Bracing, the framer installed diagonal 2x4 bracing between the studs and metal strapping on the exterior. This modified bracing is acceptable.

Item 2: The 2x10 joists above the Family Room/Kitchen area were notched on the top and bottom to attach to the steel beam. This notching is acceptable.

The modified items meet the requirements of the 2012 North Carolina Building Code for Residences.



01 21 2019