

July 11, 2018

Bim Builders
6187 NC 27 East
Coats, NC 27521

RE: Existing Tank Application HTE# 18-5-44283

Ms. Morrison,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

_____ 1. Uncover Outlet lid on septic tank and break seal (\$25.00 fee incurred)

_____ 2. Have system pumped out

_____ 3. Replace sanitary T and Lid

 X 4. Other – **Home to close to the Drain Field, 5' minimum setback. Please submit revision to Central Permitting.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E Manhart III, R.E.H.S
Environmental Health Program Specialist
Harnett County Department of Public Health

JM/kh

Copy - Central Permitting