

HTE# 18-5-44386

Harnett County Department of Public Health

30084

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Pride Homes Inc. PROPERTY LOCATION: 15 Blue Chip Ct. (Tinson Rd.) SUBDIVISION: Market Place LOT # 107

Authorized State Agent: [Signature] Date: 07/06/2018 SEE ATTACHED SITE SKETCH

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Pride Homes Inc. PROPERTY LOCATION: 15 Blue Chip Ct. (Tinson Rd.) SUBDIVISION: Market Place LOT # 107

Installation Requirements/Conditions Septic Tank Size 1000 gallons Pump Tank Size [blank] gallons

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: [Signature] Date: [blank]

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 07/06/2018 Construction Authorization Expiration Date: 07/06/2023

HTE# 18-5-44380


Permit # 30084

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Pride Homes Inc. PROPERTY LOCATOR: 15 Blue chip Ct. (Tingen Rd.) <sup>SR 1139</sup>  
SUBDIVISION Market Place LOT # 101

Authorized State Agent: [Signature] Date: 07/06/2018

ANDREW WARRIN TINGEN RD (SR 1139)



**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: <sup>Travel Home</sup> ~~Inc~~ Applicant: Pride Home Inc.  
 Address: Mamie Place lot 107 Date Evaluated: 07/05/2008  
 Proposed Facility: 482 STD Design Flow (.1949): 480 GPD Property Size: 0.50 AC  
 Location of Site: \_\_\_\_\_ Property Recorded: Yes  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
<u>1,2,3</u>	<u>L 3%</u>	<u>0-48</u>	<u>GR SL</u>	<u>vr sst top</u>		<u>48</u>			<u>P5</u>
									<u>0.7</u>

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<u>25% rd</u>	<u>25% rd</u>	Site Classification (.1948): <u>Provisionally Suitable</u>
System Type(s)	<u>25% rd</u>	<u>25% rd</u>	Evaluated By: <u>Andrew Curran, PE/HS</u>
Site LTAR	<u>0.7</u>	<u>0.7</u>	Others Present: