

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: Stencil Bldg Fac.  
 Address: Lot 3A Silas Hayes Rd Date Evaluated: 07/19/2018  
 Proposed Facility: 3000 sq ft Design Flow (.1949): 360 cfd Property Size: 3.58 Acre  
 Location of Site: \_\_\_\_\_ Property Recorded: Yes  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,3	L 5%	0-14	GR LS	VR N SW 1/2					PS
		14-48	GR SCL	VR S SW 1/2		48			0.45
2,4	L 5%	0-28	GR LS	VR N SW 1/2					PS
		28-48	GR SCL	VR S SW 1/2		48			0.45
5	L 5%	0-20	GR LS	VR N SW 1/2	7.5% <sup>3</sup> [BAAC] @ 10"				0.3

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <u>Provisionally Suitable</u>
System Type(s)	<u>25% led</u>	<u>25% led</u>	Evaluated By: <u>Andrew Curran, NEHS</u>
Site LTAR	<u>0.45</u>	<u>0.45</u>	Others Present:

