



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

February 3, 2004

Donna Clifton
195 Crystal Spring Dr.
Sanford, NC 27332

RE: Harnett County Land Use Application #04-5-8611, Existing Tank Application

Dear Ms. Clifton,

The Harnett County Department of Public Health, Environmental Health Division on January 30, 2004, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application request for a 24' swimming pool, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 1. Cannot maintain required separation between swimming pool and drainfield (15 feet).**

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R.S.

Environmental Health Specialist
Harnett County Department of Public Health

JW/sgw