



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

May 26, 2004

Chapman Wilson Pools, Spas & Home Imp.
606 Hope Mills Rd
Fayetteville, NC 28304

RE: County of Harnett Land Use Application # 04-5-9521

Dear Sirs;

The Harnett County Department of Public Health, Environmental Health Division on May 25, 2004 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application for above ground pool, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is UNSUITABLE for the addition requested. Therefore, your request for an existing tank is DENIED. The site is denied based on the following:

15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system. 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R.S.

Environmental Health Specialist
Harnett County Department of Public Health

JW/sgw