

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) John B Pitcher New Installation Septic Tank
Property Location: SR# 1705 - Old Fairground Repairs Nitrification Line
Road + on Corner of Part 2

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: _____ Lot Size: 2.13

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18* MAX in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 9-22-95

Signed: James E. Manhart


Environmental Health Specialist

* Maintain all setbacks

* Permit issued on condition of 10 Employees and any change of permit will

Result in Revocation

* DITCH depths no deeper than 18" or completion will be DENIED!




SR (1705)

VOID AFTER 5 YEARS



P.K. Noll
 (Incl. Corner)



SITE PLAN AFFR/V/L
 District RA-3P Use Sprinkler Business
 # Bedrooms N/A in new 66' x 100' bldg
 8/2/95 M. M. M. M.
 Date Zoning Administrator

Betty Lou Barefoot Johnson
 Deed Book 394, Page 669
 6.5 acres

2.69 Acres
 - 0.56 Acre R/W Road
 2.13 Acres Net

10,100
 TREES

Driveway Locations
 Parking spaces 70' x 9'
 5 parking spaces
 10' Buffer trees no more than 20' apart

N 23° 28' 48" W
 'Fairground Road' (N.C.S.R. 1705) 60' R/W
 634.78'