



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

July 20, 2005

Affordable Pools
1009 Greenhouse Drive
Hope Mills, NC 28348

DA - HTE + IVR
(left msg.)

RE: Harnett County Land Use Application HTE# 05-5-12586

Dear Applicant,

The Harnett County Department of Public Health, Environmental Health Division on July 19, 2005, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a swimming pool, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.
- 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.
- 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/sgs



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

Your location for the pool is located in the area designated for repair area for your septic system. Your option is to move pool to an area not to be used as a septic system repair area or hire a private soil consultant to locate another area for septic system repair on your lot.