

HTE# 05-50013245 Pool  
05-50013134RR

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Michael Lassiter PHONE # 919 498-3201  
ADDRESS 71 Parkton Court East Sanford NC 27332  
NAME OF MOBILE HOME PARK OR S/D Highland Forest Lot 70  
NAME OF OWNER (IF DIFFERENT) Sam  
ADDRESS OF OWNER (IF DIFFERENT) \_\_\_\_\_  
PROPERTY LOCATION: STATE ROAD NAME AND # SR 91141

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

Pool is in new Area

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

[Signature]  
Signature of Inspector

10-18-05  
Date