

HTE# 0750016920

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Wayne Colombe PHONE # \_\_\_\_\_

ADDRESS 25 Cresthaven Drive Sanford NC 27332

NAME OF MOBILE HOME PARK OR S/D Crestview Est.

NAME OF OWNER (IF DIFFERENT) Same

ADDRESS OF OWNER (IF DIFFERENT) \_\_\_\_\_

PROPERTY LOCATION: STATE ROAD NAME AND # Cresthaven

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

- THIS INSPECTION IS VOID IF:
- (1) the intended use of the septic system should change, and/or
  - (2) the system should fail or malfunction, and/or
  - (3) the owner or tenant of the property changes, and/or
  - (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

[Signature] 07-16-07  
Signature of Environmental Health Specialist Date