



Permit Inspections

Harnett County

Permit Number: CPSP08-50020076

Description: INGROUND POOL 20X40

Applied: 5/15/2008

Approved:

Site Address: 140 ADAMS POINTE CT

Issued: 5/15/2008

Finalized: 9/5/2008

City, State Zip Code: ANGIER, NC 27501

Status: CERTIFICATE OF OCCUP

Applicant: NUNEZ EZEQUIEL

Parent Permit:

Owner: NUNEZ EZEQUIEL

Parent Project:

Contractor: <NONE>

Details:

INGROUND POOL 20X40

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	6/7/2008	6/3/2008	ENVIR. HLTH. CONFIRMATION	Unassigned	APPROVED	
Notes:						
	8/1/2008	8/1/2008	R ELEC. UND. POOL	Unassigned	APPROVED	
Notes:						
	8/1/2008	8/1/2008	ONE TRADE ROUGH IN	Unassigned	APPROVED	
Notes:						
	8/20/2008	8/20/2008	PZ ZONING/FINAL INSPECTION	Unassigned	DISAPPROVED	
Notes:						
	9/5/2008	9/5/2008	PZ ZONING/FINAL INSPECTION	Unassigned	APPROVED	
Notes:						
	9/8/2008	9/8/2008	ONE TRADE FINAL	Unassigned	APPROVED	
Notes:						
When the underground pool inspection was done, the grounding/bonding points for the equipotential bonding grid were installed. The owner is a concrete contractor who has done several pool skirts and is aware of the bonding grid installation requirements. Even though the inspection was not called in, it is safe to assume the grid is in place						