



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

9/9/2021

**SUBJECT: CPSP08-50020465**  
**BUILDING RESIDENTIAL**

To: MANKA DENISE

Here are the results of all Inspections located at **345 TANNING RIDGE DR:**

Inspection Type: ENVIR. HLTH. CONFIRMATION  
Scheduled Date/Time: 7/15/2008  
Completed Date/Time: 7/17/2008  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: R ELECTRICAL UNDERGROUND  
Scheduled Date/Time: 8/1/2008  
Completed Date/Time: 8/1/2008  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

underground ok.... install wire mesh 3' out from pool deck, bond ground to wire mesh and call for inspection before pouring concrete around pool

Inspection Type: R ELEC. UND. POOL  
Scheduled Date/Time: 8/6/2008  
Completed Date/Time: 8/6/2008  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: PZ ZONING INSPECTION  
Scheduled Date/Time: 10/13/2008  
Completed Date/Time: 10/13/2008  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ONE TRADE FINAL  
Scheduled Date/Time: 10/13/2008  
Completed Date/Time: 10/10/2008  
Inspector: Unassigned  
Result: CANCELLED  
Remarks:  
Notes: THEY HAVE NOT HAD A ZONING INSPECTION.