

HTE# 10-5-25474

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Hollan Fence + Pool PHONE # 910-875-2922

ADDRESS P.O. Box 330 Raeford N.C. 28376

NAME OF MOBILE HOME PARK OR S/D Myrtlewood lot 25

NAME OF OWNER (IF DIFFERENT) DARLENA + Blanche P Smyce

ADDRESS OF OWNER (IF DIFFERENT) 150 Greenforest Circle DUNN N.C.

PROPERTY LOCATION: STATE ROAD NAME AND # Hwy 421.5

PURPOSE OF INSPECTION: Proposed Pool AS Site Plan.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markham
Signature of Environmental Health Specialist

11-2-10
Date