

HTE# 11-5-27323

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Capitol Pool + SPA PHONE # 919-665-9713

ADDRESS P.O. Box 1189 Garner N.C. 27529

NAME OF MOBILE HOME PARK OR S/D Myrtlewood S10 lot 33

NAME OF OWNER (IF DIFFERENT) Louzoles Pereda

ADDRESS OF OWNER (IF DIFFERENT) 95 Timber Creek LN DUPON N.C. 28534

PROPERTY LOCATION: STATE ROAD NAME AND # Highway 421

PURPOSE OF INSPECTION: 18x36 INGROUND Pool

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

Told Customer DO NOT DRIVE, OR CONCRETE OVER EXISTING SYSTEM.
8-22-11 - LIFT LID - NO FREE SPACE - CLEARED FILTER - FREE SPACE RETURNED.
THIS INSPECTION IS VOID IF: * Called Ben Lenthorn to pump out TANK.

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM

AUTHORIZATION OF EXISTING SYSTEM

James E. Markant REAS
Signature of Environmental Health Specialist

8-23-11
Date