

HTE# 12-5-30053

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Rising Sun Pools PHONE # 919-951-9700

ADDRESS 5608 Hillsborough ST Raleigh N.C. 27606

NAME OF MOBILE HOME PARK OR S/D Lot 9 Leigh Laurel

NAME OF OWNER (IF DIFFERENT) William STEPHENS

ADDRESS OF OWNER (IF DIFFERENT) 200 Walloncraft CT DUNN N.C. 28335

PROPERTY LOCATION: STATE ROAD NAME AND # SR1705 ON Farm Road

PURPOSE OF INSPECTION: to ground Pool 16x32

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Mantua  
Signature of Environmental Health Specialist

11-17-12  
Date