

HTE# 13-5-21540

# Harnett County Department of Public Health Improvement Permit

27485

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 2412 Byrds Mill Rd

ISSUED TO: Horraine McNeil

SUBDIVISION Cowan

LOT # 4

NEW  REPAIR  EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD

Proposed Wastewater System Type: Conventional

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:  Five years

Permit conditions: \_\_\_\_\_

No expiration

Authorized State Agent: Bryan McSwain RCHS

Date: 6/28/2013

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Horraine McNeil

PROPERTY LOCATION: 2412 Byrds Mill Rd

SUBDIVISION Cowan

LOT # 4

Facility Type: SFD  New

Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* Conventional (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable )

conventional (Repair)

### Installation Requirements/Conditions

Septic Tank Size Existing gallons

Number of trenches 1

Exact length of each trench 200 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size \_\_\_\_\_ gallons

Trenches shall be installed on contour at a

Soil Cover: 18-24 inches

Maximum Trench Depth of: 30.36 inches

(Maximum soil cover shall not exceed

(Trench bottoms shall be level to +1-1/4"

36" above the trench bottom)

in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

6 inches below pipe

Aggregate Depth: 2 inches above pipe

Conditions: PVC coming from septic tank needs 5" of fall, # 4, 5, or 57 rock to be used 12 inches total

Call before installing system. Drain line to be 15 ft from pool

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.**

**NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_

Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McSwain RCHS

Date: 6/28/2013

Construction Authorization Expiration Date: 6/28/2018

HTE# 13-5-31540

Permit # 27485

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Lorraine McNeil PROPERTY LOCATOR: 2412 Byrds Mill Rd.  
SUBDIVISION Cowen LOT # 4

Authorized State Agent: George McSwain, REHS Date: 6/28/2013

