

HTE# 14-5-33301

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME: Holland Fence & Pool PHONE # 910-818-1234

ADDRESS P.O. Box 330 Raeford N.C. 28376

NAME OF MOBILE HOME PARK OR S/D Leah Laurel lot 15

NAME OF OWNER (IF DIFFERENT) John Tyler Wilson

ADDRESS OF OWNER (IF DIFFERENT) 58 Willowcroft Duron N.C. 28334

PROPERTY LOCATION: STATE ROAD NAME AND # 311205 Old Fairground RD

PURPOSE OF INSPECTION: 18x36 Pool  
8 ft. Hot Tub

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

- THIS INSPECTION IS VOID IF:
- (1) the intended use of the septic system should change, and/or
  - (2) the system should fail or malfunction, and/or
  - (3) the owner or tenant of the property changes, and/or
  - (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM**  
**DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Manhart @ RCHHS  
Signature of Environmental Health Specialist

4-9-14  
Date